

## Certificate

for European Product Safety

Reference No. 1908822

## Socket-outlet for industrial purposes

Type designation

216MVS\*\*WH, 316MVS\*\*WH, 416MVS\*\*WH, 232MVS\*\*WH,

332MVS\*\*WH, 432MVS\*\*WH

Certificate holder

ABB s.r.o.

Vyskocilova 1561/4a 140 00 Praha 4 CZECH REPUBLIC

The product complies with the standard(s)

EN 60309-4:2007 + A1

Date of expiry

14 November 2023

EU Directive information

According to the principle of presumption of conformity, this certificate constitutes support for an EC Declaration of Conformity and CE marking

according to the Low Voltage Directive 2014/35/EU.

Additional information in Appendix.

Certification Body

Intertek Semko AB, Product Certification

Place Kista - Stockholm

Signed

Henrik Wikström

Date 25 April 2019

Page 1 of 5

This certificate is issued in accordance with the terms and conditions set out in the Appendix.





Technical data

Type designation

Rated voltage (V)

Rated current (A)

IP-Class

Standard sheet

Trade mark

Product information

Position of earthing contact

216MVS\*\*WH (\*\* denotes the position of earthing contact)

See table 104 (below)

16

67 and 69

EN 60309-2/2-I

ABB

2P+E. With switch-disconnector and manual interlock

1h, 2h, 3h, 4h, 6h, 8h, 9h and 12h

Type designation

Rated voltage (V)

Rated current (A)

IP-Class

Standard sheet

Trade mark

Product information

Position of earthing contact

316MVS\*\*WH (\*\* denotes the position of earthing contact)

See table 104 (below)

16

67 and 69

EN 60309-2/2-I

ABB

3P+E. With switch-disconnector and manual interlock.

1h, 2h, 3h, 4h, 5h, 6h, 7h, 9h and 11h

Type designation

Rated voltage (V)

Rated current (A)

IP-Class

Standard sheet

Trade mark

Product information

Position of earthing contact

416MVS\*\*WH (\*\* denotes the position of earthing contact)

See table 104 (below)

16

67 and 69

EN 60309-2/2-I

ARR

3P+N+E. With switch-disconnector and manual interlock.

1h, 2h, 3h, 4h, 5h, 6h, 7h, 9h and 11h

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect. Page 2 of 5





Type designation

Rated voltage (V)

Rated current (A)

IP-Class

Standard sheet

Trade mark

Position of earthing contact

Product information

232MVS\*\*WH (\*\* denotes the position of earthing contact)

See table 104 (below)

32

67 and 69

EN 60309-2/2-I

ARR

2P+E. With switch-disconnector and manual interlock.

1h, 2h, 3h, 4h, 6h, 8h, 9h and 12h

Type designation

Rated voltage (V)

Rated current (A)

IP-Class Standard sheet

Trade mark

Product information

Position of earthing contact

332MVS\*\*WH (\*\* denotes the position of earthing contact)

See table 104 (below)

32

67 and 69

EN 60309-2/2-I

ABB

3P+E. With switch-disconnector and manual interlock.

1h, 2h, 3h, 4h, 5h, 6h, 7h, 9h and 11h

Type designation

Rated voltage (V)

Rated current (A)

IP-Class

Standard sheet

Trade mark

Product information

Position of earthing contact

432MVS\*\*WH (\*\* denotes the position of earthing contact)

See table 104 (below)

32

67 and 69

EN 60309-2/2-I

ABB

3P+N+E. With switch-disconnector and manual interlock.

1h, 2h, 3h, 4h, 5h, 6h, 7h, 9h and 11h

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect. Page 3 of 5





## Table 104 (1 of 2)

Number of contacts	Туре	Frequency	Rated operating voltage  V	Accessories earthing- contact position <sup>a</sup>	
				16/20 A 32/30 A	63/60 A 125/100 A
3 contacts	1P+N+ ≟	50 and 60	100 to 130	4	4
	Series II	60	277	5	5
	2P+ ≟ Series I and II	50 and 60	100 to 130	4	4
			200 to 250	6	6
		50 and 60	380 to 415	9	9
			480 to 500	7	7
			Supply from an isolating transformer	12	12
		100 up to and including 300	Over 50	10	10
		Over 300 up to and including 500	Over 50	2	2
		Direct current	Over 50 up to and including 250 d	3	3
			Over 250	8	8
4 contacts	2P+N+≟ Series II	50 and 60	125/250 single-phase	12	12
	Series I	50 and 60	Supply from an isolating transformer	12	12
	3P+↓ Series I and II	50 and 60	7100 to 130	4	4
			200 to 250	9	9
			380 to 415	6	6
		60	440 to 460 b	11	11
		50 and 60	480 to 500	7	7
			600 to 690	5	5
		50 60	380 440 <sup>C</sup>	3	3
		50 and 60	1000	-	8
		100 up to and including 300	Over 50	10	10
		Over 300 up to and including 500	Over 50	2	2
5 contacts		50 and 60	57/100 to 75/130	4	4
			120/208 to 144/250	9	9
			200/346 to 240/415	6	6
			277/480 to 288/500	7	7
	3P+N+ =		347/600 to 400/690	5	5
	Series I	60	250/440 to 265/460 b	11	11
	and II	50 60	220/380 250/440 <sup>C</sup>	3	3

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

-50





## Table 104 (2 of 2)

Number of contacts	Туре	Frequency	Rated operating voltage	Accessories earthing- contact position <sup>a</sup>	
				16/20 A 32/30 A	63/60 A 125/100 A
		50 and 60	Supply from an isolating transformer	12	12
		100 up to and including 300	Over 50	10	10
		Over 300 up to and including 500	Over 50	2	2
All types		All rated operating voltage and/or frequencies not covered by other configurations.  This clock counter position can additionally be used in special applications where a distinction to standardized positions is needed		1	1

NOTE The positions shown by a dash (-) are not standardized

- a The earthing-contact position is indicated by the relevant numeral (see 7.1).
- b Mainly for marine installations.
- C Only for refrigerated containers (standardized ISO).
- d This configuration is required to have an earthing contact because it covers voltages above the upper limits of ELV (d.c.) according to IEC 60364-4-41.

Manufacturing site(s)

ABB s.r.o. Elektro-Praga Resslova 3 CZ- 466 02 Jablonec nad Nisou

CZ- 466 02 Jabionec nad Nisou CZECH REPUBLIC

According to the principle of presumption of conformity, this certificate, which includes production control, constitutes support for an EC Declaration of Conformity and CE marking according to the Low Voltage Directive 2014/35/EU.

This presumption can expire before end of validity of this certificate due to new issued Standard or Amendment and changes within the EU legislation.

This certificate replaces previously issued ref. No. 1818590 dated 14 November 2018. A new certificate has been issued on account of change certificate holder.

Certification Body

Intertek Semko AB, Product Certification

Place Kista - Stockholm

Signed

Henrik Wikström

Date 25 April 2019

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.



Intertek Semko AB Torshamnsgatan 43 Box 1103 SE-164 22 Kista Sweden Tel +46 8 750 00 00 info-sweden@intertek.com intertek.se

ABB s.r.o. Vyskocilova 1561/4a 140 00 Praha 4 CZECH REPUBLIC Handled by
Thomas Svensson
Direct telephone
+46 8 750 04 62
Reference
1910019
E-mail
thomas.svensson@intertek.com
Your reference
Libor Slazansky

14/06/2019

Socket-outlet for industrial purposes types 216MVS\*\*WH, 316MVS\*\*WH, 416MVS\*\*WH, 232MVS\*\*WH, 332MVS\*\*WH, 432MVS\*\*WH

The change design of the product mentioned above, consisting of an alternative construction (new mechanical interlock) has been tested and accepted.

Our certificate, reference No. 1908822 dated 25 April 2019 is valid on unchanged conditions also for this design.

Yours sincerely

Anneli Averland Johansson Operations Manager, Industrial

