

Issued 20.04.2015  
Version C/17.06.2022  
Technical ref. Mika Kortensniemi  
Checked by Outi Parkatti

**Application of this document**

This document is intended for use as an approval for CE-marking of below mentioned products:

**Family of**

Grid automation products

**Declaration****We ABB Oy, Distribution Solutions**

P.O. Box 699 FI-65101 Vaasa, FINLAND,

declare under our sole responsibility that the family:

Remote Monitoring and Control  
Recloser Protection and ControlREC615  
RER615

to which this declaration relates is in conformity with the following directives:

**Directives**EMC Directive 2014/30/EU  
Low Voltage Directive 2014/35/EU  
RoHS Directive 2011/65/EU

- marked

2013

**Application of the objects**

The family is intended for use in the industrial environment and to protect high voltage or high power apparatus, and thus normally used in a harsh electromagnetic environment near high voltage apparatus.

**References****Standards**

EN 60255-26:	2013
EN 61000-6-2:	2005
EN 61000-6-4:	2007
EN 60255-1:	2010
EN 60255-27:	2014

Vaasa

17.06.2022

Signed by:

Antti Hakala-Ranta, SVP Distribution Solutions

**ABB Oy, Distribution Solutions**

P.O Box 699, FI-65101 Vaasa, FINLAND

Tel: +358 10 22 11, Fax: +358 10 224 1094

www.abb.com/mediumvoltage