

Marine & Offshore

Certificate number: 06358/G0 BV File number: ACE 2/114/1 Product code: 2633H

This certificate is not valid when presented without the full attached schedule composed of 7 sections

www.veristar.com

TYPE APPROVAL CERTIFICATE

This certificate is issued to ABB STOTZ-KONTAKT GmbH

Heidelberg - GERMANY

for the type of product CIRCUIT BREAKERS (LOW VOLTAGE)

Manual Motor Starter MS325 series

Requirements:

Bureau Veritas Rules for the Classification of Steel Ships IEC 60947-2:2016 IEC 60947-4-1:2018 EC Code : 31

This certificate is issued to attest that Bureau Veritas Marine & Offshore did undertake the relevant approval procedures for the product identified above which was found to comply with the relevant requirements mentioned above.

This certificate will expire on: 04 Apr 2028

For Bureau Veritas Marine & Offshore, At BV HAMBURG, on 04 Apr 2023, Dirk Hoepfner

This certificate was created electronically and is valid without signature



This certificate remains valid until the date stated above, unless cancelled or revoked, provided the conditions indicated in the subsequent page(s) are complied with and the product remains satisfactory in service. This certificate will not be valid if the applicant makes any changes or modifications to the approved product, which have not been notified to, and agreed in writing with Bureau Veritas Marine & Offshore. Should the specified regulations or standards be amended during the validity of this certificate, the product(s) is/are to be re-approved prior to it/they being placed on board vessels to which the amended regulations or standards apply. This certificate is issued within the scope of the General Conditions of Bureau Veritas Marine & Offshore available on the internet site www.veristar.com. Any Person not a party to the contract pursuant to which this document is delivered may not assert a claim against Bureau Veritas Marine & Offshore for any liability arising out of errors or omissions which may be contained in said document, or for errors of judgement, fault or negligence committed by personnel of the Society or of its Agents in establishment or issuance of this document, and in connection with any activities for which it may provide.

The electronic version is available at: http://www.veristarnb.com/veristarnb/jsp/viewPublicPdfTypec.jsp?id=tvne9mobio BV Mod. Ad.E 530 June 2017 This certificate consists of 3 page(s)

THE SCHEDULE OF APPROVAL

<u>1. PRODUCT DESCRIPTION:</u>

MS 325 series are circuit breakers with thermal and electromagnetic protection.

1.1 - Main characteristics:

Rated voltage:690V ACNumber of poles:3Degree of protection:IP20 (Terminal compartment: IP00)Utilization category:AC 3

1.2 - Manual Motor Starters - Type design MS 325 0.16 up to 9.

Туре	Thermal	Breaking capacity (kA)		
	setting range	380-400V AC	500V AC	660-690V AC
MS 325 - 0.16	0.1 - 0.16A	100	100	100
MS 325 - 0.25	0.16 - 0.25A	100	100	100
MS 325 - 0.4	0.25 - 0.4A	100	100	100
MS 325 - 0.63	0.4 - 0.63A	100	100	100
MS 325 - 1	0.63 - 1.0A	100	100	100
MS 325 - 1.6	1.0 - 1.6A	100	100	100
MS 325 - 2.5	1.6 - 2.5A	100	100	40
MS 325 - 4	2.5 - 4.0A	100	60	10
MS 325 - 6.3	4.0 - 6.3A	100	40	7
MS 325 - 9	6.3 - 9.0A	100	30	5

1.3 - Manual Motor Starters - Type design MS 325 12.5 up to 25.

Туре	Thermal	Breaking capacity (kA)		
	setting range	380-400V AC	500V AC	660-690V AC
MS 325 - 12.5	9.0-12.5A	75	27	4,5
MS 325 - 16	12.5 - 16.0A	60	25	4
MS 325 - 20	16.0-20.0A	55	22	3,5
MS 325 - 25	20.0 - 25.0A	50	20	3

1.4 - Accessories:

Auxiliary Contact:HK-..Number of poles: 2; Rated voltage: 400V AC; Ith: 6APilot Contact:SK-..Number of poles: 2; Rated voltage: 400V AC; Ith: 6A

2. DOCUMENTS AND DRAWINGS:

- 1SBC100167C0201 dated 09.2012
<u>Note:</u> Documents filed in ACE2/114/1.
For G0 version:
- CB test certificate: CN47713 dated Aug. 06,2019

- 2CDC131046D0201#REV B dated 06.2021

3. TEST REPORTS:

- ABB STOTZ Kontakt: 4499/08 dated 02.07.2008 Note: Documents filed in ACE2/114/1.

4. APPLICATION / LIMITATION:

4.1 - Bureau Veritas Rules for the Classification of Steel Ships 4.2 - Bureau Veritas Environmental Category, **EC Code: 31**

5. PRODUCTION SURVEY REQUIREMENTS:

5.1 - The above mentioned products are to be supplied by **ABB STOTZ KONTAKT GmbH** in compliance with the type described in this certificate.

5.2 - This type of product is within the category HBV of Bureau Veritas Rule Note NR320 and as such does not require a BV product certificate.

5.3 - **ABB STOTZ KONTAKT GmbH** has to make the necessary arrangements to have its works recognised by Bureau Veritas in compliance with the requirements of NR320 for HBV products.

ABB Bulgaria EOOD 1, Varna Str. 2850 Petrich BULGARIA

6. MARKING OF PRODUCT:

According to IEC 60947 specifications.

7. OTHERS:

7.1 - It is the responsibility of ABB STOTZ KONTAKT GmbH to inform shipbuilders or their sub-contractors of the proper methods of fitting, use and general maintenance of the approved equipment and the conditions of this approval.
7.2 - This certificate supersedes the Type Approval Certificate N° 06358/F0 BV issued on 02 Feb 2018 by the Society.

*** END OF CERTIFICATE ***