

IEC

IECEE



TM

Ref. Certif. No.

CN58037

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Name and address of the applicant

Name and address of the manufacturer

Name and address of the factory

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Trademark / Brand (if any)

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

Contactor

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg GermanyABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg GermanyABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

See the Appendix

ABB

N/A

ESB100-20N, ESB100-40N;

IEC 60947-4-1:2018

00901-CB2022CQC-103694

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Oct.09,2022

Signature:

谢肇煦

Xie ZhaoXu



CB 0067721

ESB100-20N, ESB100-40N

U_{imp}:6kV;

U_i: 500V;

I_{th}: 100A;

ESB100-20N:

AC-1: U_e/I_e: AC400V/100A;

ESB100-40N:

AC-1: U_e/I_e: AC400V/100A;

DC-1: U_e/I_e: DC24V/100A, DC48V/100A, DC60V/80A, DC110V/50A, DC220V/35A;

DC-3: U_e/I_e: DC24V/100A, DC48V/70A, DC60V/45A, DC110V/25A, DC220V/7A;

U_s: 24V, 230V 40-450Hz/DC;

IP20;

2P,4P;

Auxiliary contact:(EH04-11N, EH04-20N)

I_{th}: 6A;

AC-15:U_e/I_e:120V/6A(NO/NC),240V/4A(NO/NC),415V/3A(NO/NC),500V/2A(NO/NC);

1NO1NC or 2NO

Page 1 of 1

Additional information (if necessary)

Date:

Oct.09,2022

Signature:

谢肇煦
Xie ZhaoXu



Ref. Certif. No.

CN42940

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE

Product
Produit

Electromechanical contactors for household and similar
purposes

Name and address of the applicant
Nom et adresse du demandeur

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

Name and address of the manufacturer
Nom et adresse du fabricant

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

Name and address of the factory
Nom et adresse de l'usine

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

Note: When more than one factory, please report on page 2
Note: Lorsque plus d'une usine, veuillez utiliser la 2^{ème} page

Ratings and principal characteristics
Valeurs nominales et caractéristiques principales

Ith:100A;AC-7a:Ue/Ie: AC400V/100A;Us: 24V,
230V40-450Hz/DC;IP20;2P,4P;Auxiliary contact: (EH04-11N,
EH04-20N)Ith:
6A;AC-15:Ue/Ie:120V/6A(NO/NC),240V/4A(NO/NC),415V/3
A(NO/NC),500V/2A(NO/NC);1NO1NC or 2NO

Trademark (if any)
Marque de fabrique (si elle existe)

ABB

Model / Type Ref.
Ref. De type

ESB100-20N,ESB100-40N

Additional information (if necessary may also be reported
on page 2)
Les informations complémentaires (si nécessaire, peuvent être
indiqués sur la 2^{ème} page)

A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à la

As shown in the Test Report Ref. No. which forms part
of this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce Certificat

PUBLICATION

EDITION

IEC 61095 (2nd Edition):2009

00901-CB2017CQC-078399

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme National de Certification



CHINA QUALITY CERTIFICATION CENTRE

Date: Mar.30,2018

Signature:

Wang Kejiao

Issued 2003-05
China Quality Certification Centre
Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86-10-83886666
Fax: +86-10-83886282

website
www.cqc.com.cn

CB 0043462