

CN48627

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Name and address of the applicant

Name and address of the manufacturer

Name and address of the factory

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Trademark (if any)

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

Contactor

ABB Stotz-Kontakt GmbH Eppelheimer Strasse 82 69123 Heidelberg Germany

ABB Stotz-Kontakt GmbH Eppelheimer Strasse 82 69123 Heidelberg Germany

ABB Stotz-Kontakt GmbH Eppelheimer Strasse 82 69123 Heidelberg Germany

See the Appendix

ABB

B6, BC6, B7, BC7, VB6, VBC6, VB7, VBC7

IEC 60947-4-1:2018


00901-CB2018CQC-083983

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China Tel: +86-10-83886666 Fax: +86-10-83886282 website: http://www.cqc.com.cn

Date: Oct.24,2019







B6, BC6, B7, BC7, VB6, VBC6, VB7, VBC7;

Ui:690V;

Uimp: 6kV;

Ith:20A;

B6,BC6,VB6,VBC6:

AC-1:220/230/240V/16A,380/400V/16A,440V/12A,500V/12A,690V/6A;

AC-3:Ue/Ie:690V/3.5A,500V/6.5A,400V/8.5A;

AC-3e:Ue/Ie:690V/3.5A,500V/440V/6.5A,400V/380V/240V/220V/8.5A;

DC-1:Ue/Ie:24V/16A,110V/5A,220V/0.8A;

DC-3:Ue/Ie:24V/16A,110V/1.5A,220V/0.25A;

B7,BC7,VB7,VBC7:

AC-1:220/230/240V/20A,380/400V/20A,440V/20A,500V/12A,690V/6A;

AC-3:Ue/Ie:690V/3.5A,500V/9A, 400V/11.5A;

AC-3e:Ue/Ie:690V/3.5A,500V/440V/9A, 400V/380V/240V/220V/11.5A;

DC-1:Ue/Ie:24V/16A,110V/5A,220V/0.8A;

DC-3:Ue/Ie:24V/16A,110V/1.5A,220V/0.25A;

B6...F:AC-1:220/230/240V/16A,380/400V/16A,440V/12A,500V/12A,690V/6A;

B6...P:AC-1:220/230/240V/12A,380/400V/12A,440V/12A,500V/12A,690V/6A;

B7...F:AC-1:220/230/240V/20A,380/400V/20A,440V/20A,500V/12A,690V/6A;

B7...P:AC-1:220/230/240V/12A,380/400V/12A,440V/12A,500V/12A,690V/6A;

Us: DC:17-32V, 24V,48V,110...125V,220-240V,

AC:24V,48V,110...127V,220...240V,380...415V,500V 40-450Hz;

IP20;

3P,4P;

Auxiliary contact:(body contact)

Ith:6A:

AC-15: Ue/Ie:24-240V/4A,380-440V/3A,480-500V/2A;

DC-13:Ue/Ie:24V/2.5A,125V/0.7A,250V/0.4A;

INOINC

Page 1 of 1

Additional information (if necessary)

Signature:

市南

Date: Oct.24,2019