



Marine & Offshore

Certificate number: 21626/C0 BV

File number: ACE 02/017/13

Product code: 2652H

Product code: 2652H

This certificate is not valid when presented without the full attached schedule composed of 7 sections

www.veristar.com

# TYPE APPROVAL CERTIFICATE

This certificate is issued to

## ABB STOTZ-KONTAKT GmbH

Heidelberg - GERMANY

for the type of product

## **OVER-LOAD RELAYS OR RELEASES**

TA25DU, TA42DU, TA75DU, TA80DU, TA110DU, TA200DU, TA450 DU/SU

## Requirements:

Bureau Veritas Rules for the Classification of Steel Ships IEC 60947-4-1:2012

This certificate is issued to attest that Bureau Veritas Marine & Offshore did undertake the relevant approval procedures for the product identified above which was found to comply with the relevant requirements mentioned above.

This certificate will expire on: 28 Jun 2026

For Bureau Veritas Marine & Offshore, At BV HAMBURG, on 28 Jun 2021, Dirk Hoepfner





This certificate remains valid until the date stated above, unless cancelled or revoked, provided the conditions indicated in the subsequent page(s) are complied with and the product remains satisfactory in service. This certificate will not be valid if the applicant makes any changes or modifications to the approved product, which have not been notified to, and agreed in writing with Bureau Veritas Marine & Offshore. Should the specified regulations or standards be amended during the validity of this certificate, the product(s) is/are to be re-approved prior to it/they being placed on board vessels to which the amended regulations or standards apply. This certificate is issued within the scope of the General Conditions of Bureau Veritas Marine & Offshore available on the internet site www.veristar.com. Any Person not a party to the contract pursuant to which this document is delivered may not assert a claim against Bureau Veritas Marine & Offshore for any liability arising out of errors or omissions which may be contained in said document, or for errors of judgement, fault or negligence committed by personnel of the Society or of its Agents in establishment or issuance of this document, and in connection with any activities for which it may provide.

Certificate number: 21626/C0 BV

# THE SCHEDULE OF APPROVAL

#### 1. PRODUCT DESCRIPTION:

The **TAXXXDU** (**xxx**= **25**, **42**, **75**, **80**, **110**, **200**, **450**) series are three pole thermal overload relays for direct mounting on a contactor or for single mounting.

## **Main characteristics:**

Rated Operational Current (Ie) at 40°C
Maximum Rated Operational voltage (Ue)
Rated Insulation Voltage (Ui)
Rated Operational Frequency
Rated Impulse Withstand Voltage (Uimp)
Utilization Category:

Category:

O.1 to 310A
690V AC
690V AC
50/60Hz
6kV
AC-15
DC-13
Tripping class:

## 2. DOCUMENTS AND DRAWINGS:

Catalogue: 2CDC106041C0201

Note: Documents filed in ACE 02/017/13.

## 3. TEST REPORTS:

- SEMKO AB: SE-30849, SE-30850, SE-30851, SE-30852, SE-30853, SE-30854, SE-30855, SE-30856 dated 11.12.2002
- SEMKO -Intertek Testing Services: 203596-1 dated 11.12.2002.
- ABB Control: 13092 dated 16.06.1992.

## 4. APPLICATION/LIMITATION:

- 4.1 Bureau Veritas Rules and Regulations for the Classification of Steel Ships and IEC 60947 series.
- 4.2 Bureau Veritas Environmental Category, EC Code: 31

#### **5. PRODUCTION SURVEY REQUIREMENTS:**

- 5.1 The above mentioned products are to be supplied by **ABB STOTZ KONTAKT GmbH** in compliance with the type described in this certificate.
- 5.2 This type of product is within the category HBV of Bureau Veritas Rule Note NR320 and as such does not require a BV product certificate.
- 5.3 **ABB STOTZ KONTAKT GmbH** has to make the necessary arrangements to have its works recognised by Bureau Veritas in compliance with the requirements of NR320 for HBV products:

ABB Bulgaria EOOD 1, Varna Str. 2850 Petrich BULGARIA

#### **6. MARKING OF PRODUCT:**

- According to IEC 60947 specification

#### **7. OTHERS:**

- 7.1 It is the responsibility of **ABB STOTZ KONTAKT GmbH** to inform shipbuilders or their sub-contractors of the proper methods of fitting, use and general maintenance of the approved equipment and the conditions of this approval.
- 7.2 This certificate supersedes the Type Approval Certificate N° 21626/B0 BV issued on 07 Jan 2015 by the Society.

\*\*\* END OF CERTIFICATE \*\*\*