

IEC

IECEE
CB
SCHEME

Ref. Certif. No.

CN30524

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEMESYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE

Product
Produit

Thermal Overload Relay

Name and address of the applicant
Nom et adresse du demandeurABB STOTZ-KONTAKT GmbH
Eppelheimer Strasse 82 69123 Heidelberg / GermanyName and address of the manufacturer
Nom et adresse du fabricantABB STOTZ-KONTAKT GmbH
Eppelheimer Strasse 82 69123 Heidelberg / GermanyName and address of the factory
Nome et adresse de l'usineNote: When more than one factory, please report on page 2
Note: Lorsqu'il y a plus d'une usine, veuillez utiliser la 2^{ème} pageABBXinhui Low Voltage switchgear Co.,Ltd
Jinguzhou Industrial Development Zone, Xinhui District, Jiangmen
City, Guangdong ProvinceRatings and principal characteristics
Valeurs nominales et caractéristiques principalesUi:690V;Ue=AC690V;Ie:40-51A,48-60A,57-68A,65-78A,75-87A,84-96
A;Tripping Class:10;3P;IP20; Auxiliary Contact:Ith:6A; Ue/Ie:NC:AC-1
5:AC120V/240V/3A,440V/500V/0.75A,600V/0.6A; DC-13:DC24V/1.25
A,125V/0.55A,250V/0.27A,500V/0.15A,600V/0.1A; NO:AC-15:AC120
V/240V/440V/500V/0.75A;DC-13:DC24V/1.25A,125V/0.55A,250V/0.2
7A,500V/0.15A,600V/0.1A;1NO1NCTrademark (if any)
Marque de fabrique (si elle existe)Model / Type Ref.
Ref. De type

TF96

Additional information (if necessary may also be reported
on page 2)
Les informations complémentaires (si nécessaire, peuvent être
indiqués sur la 2^{ème} page)A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à laAs shown in the Test Report Ref. No. which forms part
of this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce Certificat

PUBLICATION

EDITION

IEC 60947-4-1:2009(3rd Edition)

00901-CB2014CQC-057828

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme National de Certification

CHINA QUALITY CERTIFICATION CENTRE

Date: 2014-05-22

Signature:

Wang Kejiao

Issued 2003-05
China Quality Certification Centre
Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. ChinaTel: +86-10-83886666
Fax: +86-10-83886282website
www.cqc.com.cn

CB 0024388