



Ref. Certif. No.

CN39947

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE

Product
Produit

Electronic Overload Relay

Name and address of the applicant
Nom et adresse du demandeur

ABB STOTZ-KONTAKT GmbH
Eppelheimer Strasse 82 69123 Heidelberg, Germany

Name and address of the manufacturer
Nom et adresse du fabricant

ABB STOTZ-KONTAKT GmbH
Eppelheimer Strasse 82 69123 Heidelberg, Germany

Name and address of the factory
Nome et adresse de l'usine

ABB Xinhui Low Voltage Switchgear Co.,Ltd.
Jinguzhou Industrial Development Zone, Xinhui Region, Jiangmen
City, Guangdong Province, P.R.China

Note: When more than one factory, please report on page 2
Note: Lorsqu'il y a plus d'une usine, veuillez utiliser la 2^{ème} page

Ratings and principal characteristics
Valeurs nominales et caractéristiques principales

See the Appendix

Trademark (if any)
Marque de fabrique (si elle existe)

ABB

Model / Type Ref.
Ref. De type

EF65,EF96,EF146

Additional information (if necessary may also be reported
on page 2)
Les informations complémentaires (si nécessaire, peuvent être
indiqués sur la 2^{ème} page)

A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à la

As shown in the Test Report Ref. No. which forms part
of this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce Certificat

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**

PUBLICATION

EDITION

IEC 60947-4-1:2009 (Third Edition) + A1:2012

00901-CB2017CQC-075060



CHINA QUALITY CERTIFICATION CENTRE

Date: 2017-04-17.

Signature:

Wang Kejiao

Issued 2003-05
China Quality Certification Centre
Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86-10-83886666
Fax: +86-10-83886282

website
www.cqc.com.cn

CB 0038621



Ref. Certif. No.

CN39947

EF65, EF96, EF146
Ui: 1000V;
Ue: 1000V;
Ie: EF65-70: 25-70A, EF65-56: 20-56A,
EF96-56:20-56A, EF96-100: 36-100A, EF146:
54-150A;
Trip class:10E, 20E, 30E;
Number of poles:3P;
IP10;
Auxiliary Circuits (body contact):
1NO1NC
Ith: 6A;
AC-15: Ue/Ie: 24-240V/3A, 380-400V/1.1A,
500V/0.75A;
DC-13: Ue/Ie: 24V/1.5A, 125V/0.55A,
250V/0.27A,600V/0.1A;

Additional information (if necessary)

Information complémentaire (si nécessaire)

Date: 2017-04-17

Signature:

Wang Kejiao