

TYPE APPROVAL CERTIFICATE

Certificate No: **TAE00002GZ**Revision No: 3

Head of Section

This is to certify	:	
That the Motor Start	ter	
with type designation MS132, MS132-K / N	• •	
	ontakt GmbH en-Württemberg, Germany	
is found to comply wi DNV rules for class IEC 60947-2 IEC 60947-4-1	th sification – Ships, offshore units, and h	igh speed and light craft
Application :		
For installations ins	ide switchboards / enclosures onboard	ships and offshore units
Product(s) approve	d by this certificate is/are accepted for i	nstallation on all vessels classed by DNV.
Rated voltage (V) Rated current (A) Frequency (Hz)	690 AC 0.1 - 32 40 - 60	
Issued at Høvik on 2	2024-01-22	for DNV
This Certificate is valid until 2029-01-21 . DNV local unit: Augsburg		IOI DINV
Approval Engineer: N	larcin Tobiasz	Frederik Tore Elter

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Form code: TA 251 Revision: 2022-12 www.dnv.com Page 1 of 3

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



Job Id: **262.1-007664-7** Certificate No: **TAE00002GZ**

Revision No: 3

Name and place of manufacturer

ABB Stotz-Kontact GmbH HEIDELBERG, Germany

ABB Xinhui Low Voltage Switchgear Company Ltd 529100, JiangMen, GuangDong, China

Product description

Motor protection circuit breaker type: MS132, MS132-K (with Push-in Spring terminals) / MO132 with the following auxiliary devices (MO132 thermal tripping function deactivated):

Current limitor: S803x-SCL-SR
Aux. Switch front mounting: HKF1-xxK
Aux. Switch attached at right: HK1-xx, HK1-xxK

Aux. Switch attached at right with lead contacts: HK1-20L

Signal Switch: SK1-xx, SK1-xxK

Short circuit Signal Switch:
Undervoltage release:
UA1
Shunt release:
AA1

Rated Voltage Ue: 690* V AC

 $U_{imp} = 6 \text{ kV}$

Rated frequency: 40 - 60 Hz Utilisation category: AC3

Tripping values rated short circuit capacity:

Type MS132 and MS132-K	Thermal tripping setting ranges (A)	Rated current In / conventional free air thermal current (A)	Rated short circuit instantaneous short-circuit current setting (A)	Rated short circuit capacity I _{cs} = I _{cu} at U _e =400V (kA)	Rated short circuit capacity $I_{cs} = I_{cu}$ at U_{e} =690V (kA)	Rated short circuit capacity with current limitor* $I_{cs} = I_{cu}$ at U_{e} =690V (kA)
MS 132-0.16(K)	0.1 - 0.16	0.16	1.25 - 1.87	100	100	-
MS 132-0.25(K)	0.16 - 0.25	0.25	1.95 - 2.92	100	100	-
MS 132-0.4(K)	0.25 - 0.4	0.4	3.12 - 4.68	100	100	-
MS 132-0.63(K)	0.4 - 0.63	0.63	4.91 - 7.37	100	100	-
MS 132-1.0(K)	0.63 - 1	1.0	9.20 - 13.8	100	100	-
MS 132-1.6(K)	1 - 1.6	1.6	14.7 - 22.1	100	100	-
MS 132-2.5(K)	1.6 - 2.5	2.5	23.0 - 34.5	100	100	-
MS 132-4.0(K)	2.5 - 4	4.0	40.0 - 60.0	100	3	50
MS 132-6.3(K)	4 - 6.3	6.3	63.0 - 94.5	100	3	50
MS 132-10(K)	6.3 - 10	10	120 - 180	100	3	50
MS 132-12(K)	8 - 12	12	144 - 216	100	3	50
MS 132-16(K)	10 - 16	16	192 - 288	100	3	50
MS 132-20(K)	16 - 20	20	240 - 360	100	3	50
MS 132-25(K)	20 - 25	25	300 - 450	50	3	50
MS 132-32(K)	25 - 32	32	384 - 576	25	3	50

^{*} With current limitor S803x-series

Rated voltage auxiliary contacts Ue: 600 / 690 V AC

Form code: TA 251 Revision: 2022-12 www.dnv.com Page 2 of 3



Job Id: **262.1-007664-7** Certificate No: **TAE00002GZ**

Revision No: 3

Application/Limitation

Motor starter with thermal and magnetic release.

With Uimp = 6kV the max. rated voltage is 600 V when used in IT (ship) net. It can be used in applications with directly earthed systems with rated voltage of 400/690 V.

Type Approval documentation

Technical info:

ABB Data sheet "Manual Motor Starter MS 132"; ABB catalogue 2CDC131135C0201

Test report Paconsult report no. 09-2475 dated 2009-07-03.

Test report: SGS reports 58495801/00 to 58495801/15 & 58495802/00 to 58495802/12 issued 2009-07-13.

Test report P2649E from ABB according to IEC 60 947-2 dated 03.08.2011.

Test report P2997E from ABB according to IEC60947-4-1 and IEC 60 947-2 dated 08.06.2011.

Test report CQC: 00901-CB2017CQC-077432-2; 00901-CB2017CQC-077946; 00901-CB2017CQC-077432-1; 00901-CB2017CQC-077947; CN42163; CN42365

PaConsult 18-10034-BE-ESB 100 MS 132; ABB Tests: Glowwire MS132-K GW2017001;

Dielectric_after_Environmental_D2018015; Atex MS132-K_Supplement 1_ BVS 14 ATEX E 009;

UL: Plastics Datasheet_Cover MS132-K_Ultramid B3UGM210;

Plastics Datasheet middel and botoom Housing MS132-K Wellamid 6600-PA66-GV20 HWV0CP

Test report 00901-CB2019CQC-085478-1 according to IEC 60947-2 dated 08.11.2019

Test report 00901-CB2019CQC-085478-2 according to IEC 60947-4-1 dated 08.11.2019

IEC System For Mutual Recognition of Test Certificates For Electrical Equipment (IECEE) CB Scheme No. CN47858-M1 dated 01.09.2020

IEC System For Mutual Recognition of Test Certificates For Electrical Equipment (IECEE) CB Scheme No. CN48970 dated 02.12.2019

Tests carried out

Type tests according to DNV-CP-0396, IEC 60947-2 and IEC 60947-4-1

Marking of product

ABB Stotz - Type designation - Voltage - Current - Breaking capacity.

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable).
- Results from Routine Tests (RT) checked (if not available tests according to RT to be carried out).
- Review of type approval documentation.
- Review of possible change in design, materials and performance.
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE

Form code: TA 251 Revision: 2022-12 www.dnv.com Page 3 of 3