



中国国家强制性产品认证证书

证书编号: 2017010304032778

委托人名称、地址

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

生产者(制造商)名称、地址

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

生产企业名称、地址

ABB Bulgaria EOOD
1, Varna Str., 2850 Petrich, Bulgaria

产品名称和系列、规格、型号

辅助触头

HK1-xx, HK1-xxK, SK1-xx, SK1-xxK, CK1-xx; Ui: 690V; Uimp: 6kV; Ith: 6A; AC-15: Ue/Ie: 24V/6A, 110-120V/6A, 220-240V/4A, 400V/3A, 690V/1A; DC-13: Ue/Ie: 24V/2A, 110-125V/0.55A, 250V/0.27A, 400V/0.15A, 600V/0.15A; IP20; 型号解释见附件

产品标准和技术要求

GB/T14048.5-2017

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求,
特发此证。

发证日期: 2019 年 02 月 02 日 有效期至: 2022 年 12 月 20 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2017 年 12 月 20 日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任:

陆楠



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2017010304032778

NAME AND ADDRESS OF THE APPLICANT

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

NAME AND ADDRESS OF THE MANUFACTURER

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

NAME AND ADDRESS OF THE FACTORY

ABB Bulgaria EOOD
1, Varna Str., 2850 Petrich, Bulgaria

PRODUCT NAME, MODEL AND SPECIFICATION

Auxiliary Contact

HK1-xx, HK1-xxK, SK1-xx, SK1-xxK, CK1-xx; Ui: 690V; Uimp: 6kV; Ith: 6A; AC-15: Ue/le: 24V/6A, 110-120V/6A, 220-240V/4A, 400V/3A, 690V/1A; DC-13: Ue/le: 24V/2A, 110-125V/0.55A, 250V/0.27A, 400V/0.15A, 600V/0.15A; IP20; See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.5-2017

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification (REFNO.CNCA-C03-02:2014).

Valid from: Feb.02,2019

Valid until: Dec.20,2022

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Dec.20,2017

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附 录

第 1 页 共 1 页

证书编号: 2017010304032778

纸 号: 2221439

型号解释

HK1	-	20	L	K
1		2	3	4

1	HK1-.. Auxiliary contacts for lateral mounting 辅助触头,侧面安装 SK1-.. Signaling contacts for lateral mounting 信号触头,脱扣报警, 侧面安装 CK-.. Short-circuit Signaling contacts for lateral mounting 信号触头,短路报警, 侧面安装
2	Contact Configuration: 触点配置 11: 1 N.O. and 1 N.C. contact 1 常开, 1 常闭 20: 2 N.O. contact 2 常开 02: 2 N.C. contact 2 常闭
3	Blank: Standard product 空白 标准产品 L: with lead only for HK1-20 引导型
4	Blank: : standard version (screw terminal) 空白 标准产品螺纹端子 K: Push In terminal only for HK1-..., SK1-... 插接型端子仅对 HK1-..., SK1-...

注: 此附录与证书同时使用时有效。



主 任:

陆 楠



中国质量认证中心