

IEC

IECEE



TM

Ref. Certif. No.

CN58858

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Electronic Overload Relay

Name and address of the applicant

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

Name and address of the manufacturer

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

Name and address of the factory

ABB Xinhui Low Voltage Switchgear Co.,Ltd.
Jinguzhou Industrial Development Zone, Xinhui District,
Jiangmen City, Guangdong Province, P.R.China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

See the Appendix

Trademark / Brand (if any)

ABB

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

E45DU, EF45;

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-4-1:2018

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2022CQC-103945

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date:

Jan.11,2023

Signature:

谢肇煦

Xie ZhaoXu



CB 0070209

E45DU, EF45;

Ui: 690V;

Uimp: 6kV;

Ue: 690V;

Ie: 9~30A, 15~45A;

Trip class: 10E, 20E, 30E;

Pole:3P;

IP20

Auxiliary contacts(body contact):

Ith: 6A;

E45DU:

AC-15: Ue/Ie: 24-240V/3A, 380-400V/1.1A, 500V/0.72A;

DC-13: Ue/Ie: 24V/1.5A, 125V/0.55A, 250V/0.27A;

EF45:

AC-15: Ue/Ie: 24-240V/3A, 380-400V/1.1A, 500V/0.75A;

DC-13: Ue/Ie: 24V/1.5A, 125V/0.55A, 250V/0.27A, 600V/0.1A

1NO1NC

Page 1 of 1

Additional information (if necessary)

Date: Jan.11,2023

Signature:

谢肇煦
Xie ZhaoXu