



Ref. Certif. No.

CN58856

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Electronic Overload Relay

Name and address of the applicant

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

Name and address of the manufacturer

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

Name and address of the factory

Note: When more than one factory, please report on page 2

ABB Xinhui Low Voltage Switchgear Co.,Ltd.
Jinguzhou Industrial Development Zone, Xinhui District,
Jiangmen City, Guangdong Province, P.R.China

Ratings and principal characteristics

See the Appendix

Trademark / Brand (if any)

ABB

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

EF205-210, EF370-380;

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-4-1:2018

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2022CQC-103941

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE


Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Jan.11,2023

Signature:



Xie ZhaoXu



CB 0070211

EF205-210, EF370-380

Ui: 1000V;

Uimp: 8kV;

Ue: 1000V;

Ie: EF205-210:63-210A, EF370-380:115-380A;

Trip class: 10E, 20E and 30E;

Number of poles: 3P

Auxiliary contacts(body contact):

Ith:6A;

AC-15: Ue/Ie: 24-240V/3A, 380-400V/1.1A, 500V/0.75A;

DC-13: Ue/Ie: 24V/1.5A, 125V/0.55A, 250V/0.27A, 600V/0.1A;

1NO1NC

Page 1 of 1

Additional information (if necessary)

Date: Jan.11,2023

Signature:


Xie ZhaoXu