

GEH6282 INSTRUCTIONS

Power Break® II Circuit Breaker Accessories

Push Button Cover

Introduction

The Push Button Cover, shown in Figure 1, can be installed on 800-4000 ampere frame Power Break II circuit breakers. The catalog number is SPPBCOVER.

It consists of two unbreakable, individually sealable Lexan® shields, one over the PUSH ON button and one over the PUSH OFF button. Sealing the cover prevents accidental or unauthorized closing or opening of the circuit breaker with the local push buttons.



Figure 1. Push Button Cover.

Operation

Close the cover and put a sealing wire or wire tie in the slot. Each of the covers may be sealed independently.

Installation

Mount the Push Button Cover with one thread cutting screw centered between the PUSH ON and PUSH OFF buttons. Either of the Lexan® shields can be removed.

Each shield also has a drill point near its center. If desired, remove the shield and drill a small (approximately 1/8-inch diameter) hole through the shield to create a limited-access push button cover similar to that offered on the original Power Break circuit breaker. Reinstall and seal the shield.