



Certificate of Conformity

LOVAG-Certificate No.: IT 16.048

Page 1 of 2

This Certificate applies only to the apparatus verified. The responsibility for conformity of any apparatus having the same designation with that verified rests with the manufacturer or responsible vendor.

This certificate has been prepared according to LOVAG (Low Voltage Agreement Group) Objectives and Operating Principles of mutual recognition. The responsible certification body as a member of LOVAG issues a Certificate of Conformity with the above mentioned Standard(s) following the exclusive use of LOVAG Verification instruction wherever applicable.

Only integral reproduction of this Certificate or reproductions of this page accompanied by any page(s) on which are stated the verifications performed and the assigned rated characteristics of the apparatus verified, are permitted without written permission from the LOVAG Signatory responsible for this Certificate



Apparatus: Low voltage assembly $415V (U_e) - 3600A (I_{nA}) - 8kV(U_{imp}) - 50Hz(f) - IP65$

Designation Type
System Pro E Power 4000A

Manufacturer
ABB S.p.A. – ABB SACE Division
Via Italia, 58 - 23846 Garbagnate Monastero (LC) Italy

Applicant:
ABB S.p.A. – ABB SACE Division
Via Italia, 58 - 23846 Garbagnate Monastero (LC) Italy

Verified by: ACAE Laboratory II01

The apparatus, constructed in accordance with the description mentioned in the Report listed in this Certificate has been subjected to the series of proving verifications in accordance with IEC 61439-2 Ed.2.0 (2011-08) and EN 61439-2(2011) (This standard complies also with the requirements of the previous standard IEC 60439)

- Verification of lifting (10.2.5)
- Verification of dielectric properties (10.09)
- Verification of temperature rise-limits (10.10)

The results are shown in the Report in accordance to LOVAG. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the characteristics assigned by the manufacturer as stated at page n.2.

ACCREDIA \$\infty\$

PRD N°070B Signatory of EA, IAF and ILAC Mutual Recognition Agreements Responsible Certification Body: ACAE Via Tito Livio, 5 – 24/123 – BERGAMO (Italy)

Authorized Signature Virginio Scarioni
Date: 2016.08.30

LOVAG CERTIFICATES

LOVAG is the Low Voltage Agreement Group, which is a Mutual Agreement Group of Certification Bodies founded in 1991, which has achieved a high level of competence in testing and

certification of low voltage equipment.

LOVAG's main purpose as an Agreement Group shall be for the mutual recognition of

test reports and/or certificates of conformity by its signatories.

LOVAG presently has seven signatories (Certification Bodies) to the Agreement:

ACAE (Italy), ALPHA at VDE (Germany), Applus+ Laboratories (Spain), ASEFA (France), IMQ (Italy), Intertek Semko AB (Sweden), and SGS Belgium NV - Division SGS CEBEC

(Belgium) and employs about 40 Testing Laboratories.

Certificates

LOVAG Certificates are issued by the LOVAG Certification Bodies using verification reports and certificates in a common and recognisable format in the market. They are recognised

and accepted in the European Economic Area and elsewhere in the world.

LOVAG Instructions LOVAG uses common Instructions for verification by Testing, Comparison or Assessment

of the International and Standards covered by the Agreement and signatories to the

Agreement abide by these when verifying for LOVAG Certification.

Qualifications All signatory bodies to the Agreement are accredited to ISO IEC 17065 or EN 45011 by

accreditors being members of IAF, the International Accreditation Forum. They are located in a member country of the EU and their laboratories are accredited and/or assessed to

EN ISO/IEC 17025.

For further information contact your local certification body or the Secretariat of LOVAG by e-mail or by fax from the list below

LOVAG Certification Bodies and LOVAG Secretariat:

ACAE

Membership

Via Tito Livio 5 I-24123 Bergamo ITALY

Fax: + 39 035 453 4662 e-mail: acae@acaecert.it Web: www.acaecert.it



ASEFA

33 av du general leclerc F-92260 Fontenay-aux-roses FRANCE

e-mail: contact@asefa-cert.com Web : www.asefa-cert.com



ALPHA at VDE

Merianstrasse 28 D-63069 Offenbach GERMANY Fax: + 49 69 8306-765

e-mail: alpha@vde.com
Web: www.vde.com



Intertek Semko AB

Box 1103, Torshamnsgatan 43 SE-164 22 Kista SWEDEN

Fax: + 46 8 750 6030 e-mail: lovag@semko.se Web: www.semko.se

SGS Belgium N.V.



Applus+ Laboratories

Campus UAB E-08193 Bellaterra (Barcelona) SPAIN Fax: + 34 93 567 20 01 e-mail:

info.appluslaboratories@applus.com Web: www.applus.corp.com



Division SGS CEBEC Business Riverside Park

Business Riverside Park Avenue Internationalelaan, 55 B-1070-Brussels

BELGIUM
Fax: + 32 2 556 00 36
e-mail: silvio.piras@sgs.com
Web: www.cebec.sgs.com



IMQ S.p.A.

Via Quintiliano 43 20138 Milano ITALY

Fax: +39 0250991510 e-mail: lovag@imq.it Web: www.imq.it



LOVAG Secretariat

Lyoner Strasse 14 60528 Frankfurt am Main GERMANY

Fax: +49 6966554266 e-mail : office@lovag.net Web: www.lovag.net







Certificate of Conformity

LOVAG-Certificate No.: IT 16.048 Page 2 of 2

Lifting: 3134kg

Verification of temperature rise-limits:

Circuit

IG

Test current (Inc) A 3600

Dielectric properties:

Power frequency test voltage : 2200V, duration 5s

Impulse withstand test voltage: 9.6kV

This document includes: Test report No. 14-0455-09

Issue date : 2016.03.10





Responsible Certification Body: ACAE Via Tito Livio, 5 – 24 123 – BERGAMO (Italy)

> Authorized Signature: Virginio Scarioni Date: 2016.08.30