



Reference No. SE-S-2101503

Circuit-breakers for overcurrent protection

dir care or	editers for	OVCICALI	one pr	
Type designation:	S20*P**			

Certificate holder:

ABB STOTZ-KONTAKT GMBH
Eppelheimer Strasse 82
69123 Heidelberg, Germany

The product complies with EN 60898-1:2003+A1+A11+A12+A13 **the standard(s):**

Date of expiry: 28 May, 2024

EU Directive information: According to the principle of presumption of conformity, this certificate

constitutes support for an EC Declaration of Conformity and CE marking

according to the Low Voltage Directive 2014/35/EU.

Additional information in Appendix

Certification Body: Intertek Semko AB, Product Certification Place: Kista - Stockholm

Signed: Date: 11 November, 2021

Henrik Wikström

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement, Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

Intertek Semko AB Page 1 of 3



APPENDIX:

Reference No. SE-S-2101503

Technical Data:

Type designation S20*P**

Rated voltage (V) AC 230 (Poles 1+N)

AC 230/400 (Poles 1)

AC 400 (Poles 2; 3; 3+N; 4)

Rated current (A) B: 6; 10; 13; 16; 20; 25; 32; 40; 50; 63

C: 0,5; 1; 1,6; 2; 3; 4; 6; 8; 10; 13; 16; 20; 25; 32; 40; 50; 63

D: 0,5; 1; 1,6; 2; 3; 4; 6; 8; 10; 13; 16; 20; 25

Frequency (Hz) 50/60

Poles No. 1P; 1P+N; 2P; 3P; 3P+N, 4P

IP-Class 20 Trademark ABB

Test Report 247071-TL3-000 to 247071-TL3-081

Product information B, C and D –Type Icn= 25000A (0,5-25A)

Icn= 15000A (32-63A)

Energy limiting class 3 (Type B and C)



This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

Intertek Semko AB Page 2 of 3



APPENDIX:

Reference No. SE-S-2101503

_	.,
Type	ĸev

S20* P * *

1st * = Number of poles: 1; 1P-NA; 2; 3; 3P-NA; 4

2nd * = Instantaneous tripping current: B; C; D

3rd * = Rated current; 0,5-63A

This certificate replaces previously issued ref. No. 1620877 dated 28 December 2016. A new certificate has been issued on account of renewal.

This certificate is based on CCA with ref. No. DE1 34737 dated 2019-07-09, issued by VDE.

According to the principle of presumption of conformity, this certificate, which includes production control, constitutes support for an EC Declaration of Conformity and CE marking according to the Low Voltage Directive 2014/35/EU.

This presumption can expire before end of validity of this certificate due to new issued Standard or Amendment and changes within the EU legislation.

Manufacturing Sites: ABB STOTZ-KONTAKT GMBH

Eppelheimer Strasse 82 69123 Heidelberg

Germany

Certification Body: Intertek Semko AB, Product Certification Place: Kista - Stockholm

Signed: Date: 11 November, 2021

Henrik Wikström

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

Intertek Semko AB Page 3 of 3