

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

Circuit-breaker

Name and address of the applicant

ABB-Stotz-Kontakt GmbH  
Eppelheimer Straße 82, 69123 Heidelberg  
GERMANY

Name and address of the manufacturer

ABB-Stotz-Kontakt GmbH  
Eppelheimer Straße 82, 69123 Heidelberg  
GERMANY

Name and address of the factory

ABB-Stotz-Kontakt GmbH  
Eppelheimer Straße 82, 69123 Heidelberg  
GERMANY*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

☐ Additional Information on page 2In: 0,5 A - 63 A; Un: AC 230/400 V; AC 230 V; AC 400 V  
Number of poles: 1; 2; 3; 4; 1+N; 3+N

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

CTF Stage 2

Model / Type Ref.

Series S 200MT

Additional information (if necessary may also  
be reported on page 2)

Instantaneous tripping current: B; C; D; Icn: 10000 A

☐ Additional Information on page 2A sample of the product was tested and found  
to be in conformity withIEC 60898-1:2015  
IEC 60898-1:2015/AMD1:2019As shown in the Test Report Ref. No. which  
forms part of this Certificate

295527-TL3-000 to 295827-TL3-089

This CB Test Certificate is issued by the National Certification Body

**VDE** Prüf- und Zertifizierungsinstitut GmbH  
**VDE** Testing and Certification Institute  
Zertifizierungsstelle und internat. Angelegenheiten  
Certification Body and internat. Affairs

Date: 2022-07-15

Signature:



T. Baumann