

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Circuit-breaker

Name and address of the applicant

ABB-Stotz-Kontakt GmbH
Eppelheimer Straße 82, 69123 Heidelberg
GERMANY

Name and address of the manufacturer

ABB-Stotz-Kontakt GmbH
Eppelheimer Straße 82, 69123 Heidelberg
GERMANY

Name and address of the factory

ABB LV Installation Materials Co. Ltd., Beijing
No.17, Kangding Street,, Beijing Economic-Techn. Developm.
Area, 100176 Beijing, Beijing
CHINA*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

☐ Additional Information on page 2AC 230V; AC 230/400V; AC 400V; B 6-63A; C/D 0,5-63A
Number of poles: 1; 2; 3; 4; 1+N; 3+N
Instantaneous tripping current: B; C; D; Icn: 10kA

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

CTF Stage 2

Model / Type Ref.

Serie / series S 20. M

Additional information (if necessary may also
be reported on page 2)☐ Additional Information on page 2A sample of the product was tested and found
to be in conformity withIEC 60898-1:2015
IEC 60898-1:2015/AMD1:2019As shown in the Test Report Ref. No. which
forms part of this Certificate

298641-TL3-000; 298641-TL3-1

This CB Test Certificate is issued by the National Certification Body

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierungsstelle und internat. Angelegenheiten
Certification Body and internat. Affairs

Date: 2022-08-02

Signature:



J. Richter