### 2NGA000957

## **Declaration of Conformity**

Issued 15.04.2021 Version A/15.04.2021 Technical ref. Mika Kortesniemi Checked by Outi Parkatti

# Application of this document

This document is intended for use as an approval for UKCA-marking of below mentioned products:

| Family of | 620 series |
|-----------|------------|

#### **Declaration**

### We ABB Oy, Distribution Solutions

P.O. Box 699 FI-65101 Vaasa, FINLAND, declare under our sole responsibility that the family:

| Feeder Protection and Control      | REF620 |
|------------------------------------|--------|
| Motor Protection and Control       | REM620 |
| Transformer Protection and Control | RET620 |

to which this declaration relates is in conformity with the following relevant statutory requirements:

Electrical Equipment (Safety) Regulations 2016

Electromagnetic Compatibility Regulations 2016

The Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012

# Application of the objects

References

The family is intended for use in the industrial environment and to protect high voltage or high power apparatus, and thus normally used in a harsh electromagnetic environment near high voltage apparatus.

| Designated standards | BS EN 60255-26:  | 2013 |
|----------------------|------------------|------|
|                      | BS EN 61000-6-2: | 2005 |
|                      | BS EN 61000-6-4: | 2007 |
|                      | BS EN 60255-1:   | 2010 |
|                      | BS EN 60255-27:  | 2013 |
|                      |                  |      |

Vaasa 15.04.2021

Signed by:

Antti Hakala-Ranta, Senior Vice President Distribution Solutions



**ABB Oy, Distribution Solutions** 

P.O Box 699, FI-65101 Vaasa, FINLAND Tel: +358 10 22 11, Fax: +358 10 224 1094 www.abb.com/mediumvoltage