

CERTIFICATE OF COMPLIANCE

Certificate Number 20190227-E353291
Report Reference E353291-20190221
Issue Date 2019-FEBRUARY-27

Issued to: ABB AB JOKAB SAFETY
Varlbergsvagen 11 SE-434 39 Kungsbacka SWEDEN

**This certificate confirms that
representative samples of**

EMERGENCY STOP DEVICES

Emergency Stop Devices, Models HD5 followed by S or B
or C or R followed by 1XX, 2XX, 3XX, 4XX, 9XX (where xx
can be 01-99)

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.


Standard(s) for Safety: UL60947-5-5 - Low-Voltage Switchgear and Controlgear
CAN/CSA C22.2 No. 14-18 - Industrial Control Equipment

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

