

Part must comply with company doc. 9- Interpret drawing in accordance with As	
Tolerance	Prepared
X.XX = None	PLH
$X.XXX = \pm.030$	Approved
	GTM
	Division/Dept.
	DMPC/Pov

NOTES:

- 1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE, AND LOCAL CODES.
- 2. REFER TO PRODUCT DOCUMENTATION FOR ADDITIONAL DETAILS PRIOR TO SITE PREPARATION OR INSTALLATION.
- 3. OPERATING TEMPERATURE RANGE: 0° TO 40°C.
- 4. SYSTEM COOLING REQUIREMENTS: EXHAUST AIR COOLED.
- 5. SYSTEM WEIGHT: = 6560 LBS (2982 kg)
- OPERATIONAL ACCESS VIA FRONT DOORS. MAINTENANCE AND CONNECTION ACCESS VIA FRONT DOORS AND REMOVEABLE SIDE PANEL OR REAR DOORS (DEPENDING ON ACCESS SEE NOTE 7).
- 7. RECOMMENDED MINIMUM CLEARANCES: FRONT = 42"

- 8. SYSTEM MUST HAVE ALL PANELS AND DOORS INSTALLED FOR PROPER OPERATION.
- 9. FINISH: FRAME AND OUTER PANELS, POWDER COAT INTERIOR, GALVANIZED ZINC ELECTROPLATE.
- 10. CABLE ENTRY:
 - TOP ENTRY TOP EXIT BOTTOM ENTRY BOTTOM EXIT TOP ENTRY BOTTOM EXIT

BOTTOM ENTRY - TOP EXIT, CONSULT FACTORY

- 11. BUSBAR TERMINALS FURNISHED WITH NEMA 2-HOLE LANDINGS.
- SEE SHEET 2 DETAILS A, B, AND C.
- 12. 2000A DESIGNED FOR CABLE SIZES UP TO 6X 750 MCM PER PHASE.



