

20 October 2017

601 Blackburn Road
Notting Hill VIC 3168

ABB Australia Pty Limited

Dear Sir / Madam,

APPROVAL OF PRESCRIBED EQUIPMENT

Enclosed is the Certificate(s) in respect to your recent application received by Energy Safe Victoria.


Please take time to check the certificate to ensure that all details are correct in accordance with your application, and that you understand all of the conditions imposed on the approval.

Should you have any queries, please contact Jean Marie Ntahonkiriye on telephone (03) 9203 9700, or email jntahonkiriye@esv.vic.gov.au

Any samples that accompanied your application are available for collection, and if not collected within 20 business days of the date hereon may be disposed of.

Notification must be given to Energy Safe Victoria of any change of registered Address within 20 business days.

Yours sincerely



DIRECTOR OF ENERGY SAFETY

Ref: ESV170519/00

Certificate Number: ESV170519/00

Certificate of Approval

This is to certify that the Director of Energy Safety has approved the electrical equipment described hereunder.

Registered Declarant: ABB Australia Pty Limited
601 Blackburn Road
Notting Hill VIC 3168

Required Marking: ESV170519

Electrical equipment covered by this approval must comply in all respects with the approved article, and prior to being supplied or offered for supply, must be clearly and indelibly marked with the required marking indicated above, or the Regulatory Compliance Mark (RCM) provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled.

Any modifications to the electrical equipment or its place of manufacture must be approved by Energy Safe Victoria prior to the equipment being supplied or offered for supply.

Notification must be given to Energy Safe Victoria of any change to the name or address of the holder of the certificate within 20 business days.

ARTICLE DETAILS

Electrical Equipment:	Level 3 Residual Current Device Residual Current Device
Relevant Standards:	AS/NZS 61009.1:2015
Expiry Date:	20 October 2022
Conditions of Approval:	Alternate approval marking ESV170173



Approval details

Addition of C25 for 30 mA In and C6, C10, C16 & C20 for 10mA In.
--

Model	DSN201
Rated at	Input: 240VAC, 6;10;16;20A, 50Hz
Trade Name	ABB, DSN201
Comments	


Model	DSN201C25
Rated at	Input: 240VAC, 25A, 50Hz Output: 240VAC, 25A, 50Hz
Trade Name	ABB
Comments	

Model	DSN201C6A10
Rated at	Input: 240VAC, 6 A, 50Hz Output: 240VAC, 6 A, 50Hz
Trade Name	ABB
Comments	

Model	DSN201C10A10
Rated at	Input: 240VAC, 10 A, 50Hz Output: 240VAC, 10 A, 50Hz
Trade Name	ABB
Comments	

Model	DSN201C16A10
Rated at	Input: 240VAC, 16 A, 50Hz Output: 240VAC, 16 A, 50Hz
Trade Name	ABB
Comments	

Model	DSN201C20A10
-------	--------------



Certificate Number: ESV170519/00

Rated at	Input: 240VAC, 20 A, 50Hz Output: 240VAC, 20 A, 50Hz
Trade Name	ABB
Comments	


Model	DSN201C6A30
Rated at	Input: 240VAC, 6 A, 50Hz Output: 240VAC, 6 A, 50Hz
Trade Name	ABB
Comments	

Model	DSN201C10A30
Rated at	Input: 240VAC, 10 A, 50Hz Output: 240VAC, 10 A, 50Hz
Trade Name	ABB
Comments	

Model	DSN201C16A30
Rated at	Input: 240VAC, 16 A, 50Hz Output: 240VAC, 16 A, 50Hz
Trade Name	ABB
Comments	

Model	DSN201C20A30
Rated at	Input: 240VAC, 20 A, 50Hz Output: 240VAC, 20 A, 50Hz
Trade Name	ABB
Comments	

Model	DSN201C25A30
Rated at	Input: 240VAC, 25 A, 50Hz Output: 240VAC, 25 A, 50Hz
Trade Name	ABB
Comments	



Certificate Number: ESV170519/00



A handwritten signature in black ink, appearing to read "A. J. Gleeson".