


TITLE Declaration of Conformity – ECO LED IP40 batten, diffused AC & emergency, LiFePO4 battery					
PREPARED: G Grover	CHECKED: Stephen Charlton	APPROVED: Stephen Charlton	DOCUMENT NUMBER BPDC003	ISSUE: A	
DATE: 27/05/19	DATE: 28/05/19	DATE: 28/05/19	DATE: 28/05/19	DATE: 28/05/19	

Product covered by this declaration –

ECOBAT4AC ECOBAT4EM

Product Description –

ECO LED IP40 diffused batten, non-monitored. The batten comprising base including control gear, LED light source combined with diffuser and LiFePO4 battery pack in EM version.

Declaration –

The product listed above is designed and manufactured to comply with the relevant standards as listed below, provided it is correctly installed and maintained.

Applicable Standards –

AS/NZS 60598.1:2017	Luminaires General requirements and tests
AS/NZS 60598.2.22:2005	Luminaires Particular requirements - Luminaires for emergency lighting
AS/NZS 2293.3:2018	Emergency lighting and exit signs for buildings Emergency luminaires and exit signs
AS/NZS CISPR 15	Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment



Signature:

Signed for and on behalf of ABB Australia Pty Ltd

Name & position, as authorized by the issuer	Stephen Charlton Product Manager - Emergency Lighting - Asia
Date of Issue	28/05/2019