



Ref. Certif. No.

CN48447-M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Switch-disconnector-fuse

Name and address of the applicant

ABB Oy
Muottitie 2A FI-65320 VAASA, Finland

Name and address of the manufacturer

ABB Oy
Muottitie 2A FI-65320 VAASA, Finland

Name and address of the factory

Note: When more than one factory, please report on page 2

ABB Bulgaria EOOD – Rakovski branch
BULGARIA, 4142 Village of Stryama, Region of Plovdiv,
Municipality of Rakovski, Rakovski Industrial Zone, 14
Industrial Road 1, nr,14-18

Ratings and principal characteristics

Uimp: 8kV;Ui: 1000V;Ith: 125A(690V)/160A(500V);AC-23A:
Ue/ Ie: 690V/125A, 500V/160A; Iq:
120kA(500V) ,100kA(690V);3P;IP41(front);50/60Hz

Trademark (if any)

ABB

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

XRG00

Additional information (if necessary may also be reported on page 2)

Original CB certificate No. is CN48447, dated 2019-10-22.
This modification is to add another monitoring communication unit and to change the address of the factory.

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2007 (5th Edition) + AMD1:2010 +
AMD2:2014;IEC 60947-3:2008(3rd Edition) + AMD 1:2012 +
AMD 2:2015

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2019CQC-086650-M1

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date:

Apr.26,2020

Signature:

Lu Mei

CB 0056756