

Page 1 of 3

Certificate No: LR21431404TA Issue Date: 25/11/2021 Expiry Date: 24/11/2026

Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

Manufacturer ABB Electrification Sweden AB

Address Motorgränd 20, Västeras, 72161, Sweden

Place of Production ABB Electrification Sweden AB

Motorgränd 20, Västeras, 72161, Sweden

Type Contactors

Description Two-pole low voltage DC contactors, GF-series

Auxiliary contact block, CAL20

Trade Name GF875-20, GF1050-20, GF1325-20

Application Marine, offshore and industrial applications for use in general power

distribution zones in environmental categories ENV1, ENV2 and ENV3 as

defined in Lloyd's Register's Type Approval System, Test Specification Number

1 - December 2020.

Specified Standard IEC 60947-4-1: 2018

IACS E10 Rev. 8 / 2021

Ratings Ambient operating temperature: +5 °C...+70 °C

GF875-20 & GF1050-20:

Rated operational voltage (Ue): up to 1500 VDC (restricted to 750 VDC per pole)

Jochen Koerner

Senior Specialist to Lloyd's Register EMEA A member of the Lloyd's Register group

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.



Page 2 of 3

Certificate No: LR21431404TA Issue Date: 25/11/2021 Expiry Date: 24/11/2026

Type Approval Certificate

Rated Frequency: 50/60 Hz

Rated operational current DC-PV3 (Ie): 875 to 1050 A (1500 V / 60 °C)

Rated operational current DC-1 (Ie): 210 A (1500 V / 70 °C)

Rated operational voltage (Ue): up to 1500 VDC (restricted to 750 VDC per pole)

Rated Frequency: 50/60 Hz

Rated operational current DC-1 (Ie): 210 A (1500 V / 70 °C)

Auxiliary contact block CAL20 (1 NO + 1 NC): Rated operational voltage (Ue): 24 - 690 VAC

Rated Frequency: 50/60 Hz

Software version PLC-Controller: 2.1.x

For detailed ratings, pls. refer to appendix.

Other Conditions

Manufacturer's derating table is to be observed.

Ventilation arrangement is to be arranged as per manufacturer's instructions.

The operational voltage per pole is 750 VDC (1L1-2T1 and 3L2-4T2).

To switch 1500 VDC, two poles (1L1 – 2T1 – 3L2 – 4T2) of GF are required to be

connected in series.

Type Approval does not eliminate the need for normal inspection and survey

procedures required by the Rules and Regulations.

If the specified standards are amended during the validity of this certificate, the product is to be re-approved prior to it being supplied to vessels to which

the amended standards apply.

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.



Page 3 of 3

Certificate No: LR21431404TA Issue Date: 25/11/2021

Expiry Date: 24/11/2026

Type Approval Certificate

This certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid Certificate.

The Design Appraisal Document HTS/ETS 41899-21/MK/TW and its supplementary Type Approval Terms and Conditions form part of this Certificate.

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.



Page 1 of 2

Certificate No: LR21431404TA Issue Date: 25/11/2021 Expiry Date: 24/11/2026

Appendix

DESCRIPTION

Two-pole low voltage DC contactors, GF-series Auxiliary contact block, CAL20

RATINGS

Utilization characteristics acc. to IEC 60947-1 / 60947-4-1:

Contactor type		GF87	'5-20		
Rated insulation voltage (Ui)	1500 VDC				
Rated impulse withstand voltage (Uimp)	8 kV				
Rated Frequency	50/60 Hz				
Degree of protection	00				
Rated thermal current (Ith)	875 A				
Utilization category	DC-PV3		DC	DC-1	
Ambient temperature	60 °C	70 °C	60 °C	70 °C	
Rated operational voltage (Ue)	1500 VDC	1500 VDC	1500 VDC	1500 VDC	
Rated operational current (le/lscl)	875 / 210 A	650 / 210 A	210 A	210 A	

Contactor type	GF1050-20			
Rated insulation voltage (Ui)	1500 VDC			
Rated impulse withstand voltage (Uimp)	8 kV			
Rated Frequency	50/60 Hz			
Degree of protection	00			
Rated thermal current (Ith)	1050 A			
Utilization category	DC-PV3 D		C-1	
Ambient temperature	60 °C	70 °C	60 °C	70 °C
Rated operational voltage (Ue)	1500 VDC	1500 VDC	1500 VDC	1500 VDC
Rated operational current (le/lscl)	1050 / 210 A	850 / 210 A	210 A	210 A

Contactor type	GF1325-20			
Rated insulation voltage (Ui)	1500 VDC			
Rated impulse withstand voltage (Uimp)	8 kV			
Rated Frequency	50/60 Hz			
Degree of protection	00			
Rated thermal current (Ith)	1325 A			
Utilization category	- DC-1		C-1	
Ambient temperature	ı	-	60 °C	70 °C
Rated operational voltage (Ue)	-	-	1500 VDC	1500 VDC
Rated operational current (le/lscl)	-	-	210 A	210 A

The operational voltage per pole is 750 VDC. (1L1-2T1 and 3L2-4T2) To switch 1500 VDC, two poles (1L1-2T1-3L2-4T2) of GF are required to be connected in series.

Rated control circuit voltage supply (Uc):

Code 51: Uc = 24...60 VAC / 20...60 VDC (with PLC-control)
Code 53: Uc = 100...250 VAC / 100...250 VDC (with PLC-control)

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

R R

> LX LR LR

IR IR IR

R R

IR IR

<u>に</u>



Page 2 of 2

Certificate No: LR21431404TA Issue Date: 25/11/2021

Expiry Date: 24/11/2026

RATINGS (continued)

Contact utilization characteristics acc. to IEC 60947-1 / 60947-5-1:

Auxiliary contact block	CAL20		
Rated insulation voltage (U¡)	690 V		
Rated impulse withstand voltage (Uimp)	6 kV		
Rated operational voltage (Ue)	24 – 690 VAC		
Rated Frequency	quency 50/60 Hz		
Degree of protection	00		
Rated thermal current (Ith) θ ≤ 40 °C	16 A		

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

R R

> R R

IR IR

K R

R R

K R

<u>L</u>R