

IEC

IECEE

®

TM

Ref. Certif. No.

CN59476

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Switch-disconnector

Name and address of the applicant

ABB Oy
Muottitie 2A FI-65320 VAASA, Finland

Name and address of the manufacturer

ABB Oy
Muottitie 2A FI-65320 VAASA, Finland

Name and address of the factory

Note: When more than one factory, please report on page 2

ABB Bulgaria EOOD – Rakovski branch
BULGARIA, 4142 Village of Stryama, Region of Plovdiv, Municipality of
Rakovski, Rakovski Industrial Zone, 14 Industrial Road 1, nr,14-18

Ratings and principal characteristics

Uimp: 8kV;Ui:1000V;Ith:2000A(BZL2000A,BZH2000A,BZH2000A-BC),1600A(BZH1600A-BC);
Icm:30kA,Icw:30kA/1s;50/60Hz,IP30(front);3P: BZL2000A,BZH2000A: AC-21B:Ue/Ie:AC690V/2000A;
AC-22B:Ue/Ie:AC500V/2000A; BZH2000A-BC:AC-21B:Ue/Ie:AC690V/2000A;
BZH1600A-BC:AC-21B:Ue/Ie:AC690V/1600A

Trademark / Brand (if any)

ABB

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

BZL2000A, BZH2000A, BZH2000A-BC, BZH1600A-BC

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-3:2020 in conjunction with IEC 60947-1:2020

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2022CQC-103822

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Apr.24,2023

Signature:

谢肇煦

Xie ZhaoXu



CB 0072257