

10	Q	()	4 0 0 0 0000	50	8	94 02 02 05 05 05 05 05 05 05 05 05 05 05 05 05	g g g	200	300		
				CURREN	IT IN	AMPERES	10		100		

MVI Fault Interrupter	CO-11-2 Relay	30-900 Ampere	
MINIMUM TRIPPING			
 Notes: 1. Tested per C37.60 2. Accuracy is equal to +/- 10% of the current or time which ever is greater. 3. Minimum power up current: 15 Amperes 4. Curves are applicable to the operating range of -40°C to +65°C. 	 5. CT current sensing capability range: 10 -10,000 amperes RMS 6. Curves and trips are set using a personal computer or a control panel 7. The total clearing time-current characteristics curves represent the total time required to detect and interrupt the fault current 8. This curve in its entirety, including the title block, should be printed on a 11"x 17" sheet in order to conform with the C37.41 curve presentation standard (5.6 cm/decade). 	CO-11-2 Relay 30-900 Ampere	
elastimold [®]	497 Schooley's Mountain Road Hackettstown NJ, 07840	Issue Date: December 13, 2022	
		Reference number: MVI-TCC-09	