

ABB LV Installation Materials Co., Ltd. Beijing **TEST REPORT**

SCOPE OF WORK

IP55 LID/ WSC101, WSC201

REPORT NUMBER

230112080GZU-001

ISSUE DATE

Mar. 8, 2023

PAGES

11

DOCUMENT CONTROL NUMBER

General-ACCE-001 (3-Feb-2021)

© 2021 INTERTEK



Applicant Name : ABB LV Installation Materials Co., Ltd. Beijing
Applicant Address : No.17 Kangding Street, Beijing Economic-Technological Development Area
100176, P.R. China

Sample Description:

Product Name : IP55 lid
Brand Name : ABB
Model No. : WSC101, WSC201
Rating : IP55

Date Received : 2023-01-18
Date Test Conducted : 2023-01-19 ~ 2023-02-14


Test specification:

Test Requested : IP55

Test Method (standards) : Refer to IEC 60529: 1989 + A1:1999 + A2: 2013, Clause 13.5 and Clause 14.2.5


Test Result : No talcum powder inside, no water inside, electrical strength test passed.

Prepared by:



Jeff Dong
Engineer

Reviewed by:



Hunter Chu
Reviewer