



Ref. Certif. No.

SE-106504**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME****CB TEST CERTIFICATE**

Product

Switch-Isolator

Name and address of the applicant

ABB LV Installation Materials Co., Ltd. Beijing
No. 17 Kangding Street, Beijing Economic-Technological
Development Area 100176, P.R.China

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Note: When more than one factory, please report on page 2

Wenzhou Daguan Electrics Co., Ltd.
Dongmeng Industrial Zone, Wuniu Town, Yongjia County,
Wenzhou, Zhejiang, China 325103

Ratings and principal characteristics

Ue= 240V~(2P), 240/415V~(4P), 50/60Hz
Ie= 20, 32, 45, 63A
Icw= 15Ie, 1s; Icm= 4500A; Cat.: AC-23A
Ui= 630V, Uimp= 2,5kV, IP66

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

WSD**CL

Additional information (if necessary may also be reported on page 2)

See page 2

A sample of the product was tested and found to be in conformity with

IEC 60947-3:2020

As shown in the Test Report Ref. No. which forms part of this Certificate

211000184SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden**intertek**

Signature:

Leif Mattsson

Date: 01 December, 2021



Ref. Certif. No.

SE-106504

Additional information

Description of model WSD**CL:

1st * denotes the number of poles: 2 for 2 poles, 4 for 4 poles

2nd * denotes the rated current I_e without "A": 20, 32, 45, 63

This certificate replaces previously issued certificate ref. No. SE-89632 dated 18 January 2018 for the same model.
A new certificate has been issued on account of updating standard.

Date: 01 December, 2021

Signature: 