



Total Quality. Assured.

ABB LV Installation Materials Co., Ltd. Beijing **TEST REPORT**

SCOPE OF WORK

IP66 BOX WITH LID/ WSC102, WSC202

REPORT NUMBER

221108193GZU-001

ISSUE DATE

Mar. 3, 2023

PAGES

11

DOCUMENT CONTROL NUMBER

General-ACCE-001 (3-Feb-2021)

© 2021 INTERTEK



Applicant Name : ABB LV Installation Materials Co., Ltd. Beijing
Applicant Address : No.17 Kangding Street, Beijing Economic-Technological Development Area
100176, P.R. China

Sample Description:

Product Name : IP66 Box with lid
Brand Name : ABB
Model No. : WSC102, WSC202
Rating : IP66

Date Received : 2022-12-08
Date Test Conducted : 2022-12-30 ~ 2023-01-14


Test specification:

Test Requested : IP66

Test Method (standards) : Refer to IEC 60529: 1989 + A1:1999 + A2: 2013, Clause 13.6 and Clause 14.2.6


Test Result : No talcum powder inside, no water inside, electrical strength test passed.

Prepared by:



Jeff Dong
Engineer

Reviewed by:



Hunter Chu
Reviewer