



Ref. Certif. No.

CN46281

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

**CB TEST CERTIFICATE**

Product

Frontal Electronic Timer

Name and address of the applicant

ABB France  
3 Rue Jean Perrin CS 90009 69687 Chassieu Cedex, France

Name and address of the manufacturer

ABB France  
3 Rue Jean Perrin CS 90009 69687 Chassieu Cedex, France

Name and address of the factory

ABB Xinhui Low Voltage Switchgear Co.,Ltd.  
Jinguzhou Industrial Development Zone,Xinhui  
Region,Jiangmen City,Guangdong Province

*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

Uimp: 4kV; Ui: 400V; Ue/Ie: AC-15: 240V/1.5A;DC-13:  
24V/1A;Ith: 5A;Utilization category: AC-15, DC-13;IP20

Trademark (if any)

ABB

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

TEF5-ON, TEF5-OFF, TEF4-ON, TEF4-OFF, TEF4S-ON,  
TEF4S-OFF

Additional information (if necessary may also be  
reported on page 2)

A sample of the product was tested and found  
to be in conformity with

IEC 60947-5-1:2016(4th Edition)

As shown in the Test Report Ref. No. which  
forms part of this Certificate

GQI-POW-2019001

This CB Test Certificate is issued by the National Certification Body

**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China  
Tel: +86-10-83886666 Fax: +86-10-83886282  
website: <http://www.cqc.com.cn>



Date: Apr.02,2019

Signature:

陆梅

Lu Mei

**CB 0051619**