

IEC

IECEE



Ref. Certif. No.

CN53617

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Auxiliary Contact

Name and address of the applicant

ABB France
3 Rue Jean Perrin CS 90009 69687, Chassieu Cedex, France

Name and address of the manufacturer

ABB Xinhui Low Voltage Switchgear Co.,Ltd.
Jinguzhou Industrial Development Zone, Xinhui District,
Jiangmen City, Guangdong Province, P.R.China

Name and address of the factory

ABB Xinhui Low Voltage Switchgear Co.,Ltd.
Jinguzhou Industrial Development Zone, Xinhui District,
Jiangmen City, Guangdong Province, P.R.China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Ui: 690V;Uimp: 6kV;Ith: 10A;AC-15:Ue/Ie:24-127V/6A, 220-240V/4A,
380-440V/3A, 500-690V/2A,DC-13:Ue/Ie:24V/6A, 48V/2.8A, 72V/1A,
110V/0.55A, 125V/0.55A, 220-250V/0.3A;IP20

Trademark / Brand (if any)

ABB

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

CA3;

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-5-1:2016(4th Edition)

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2021CQC-097278

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: May.18,2021

Signature:

Lu Mei

CB 0062519