

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE Product Contactor Name and address of the applicant **ABB** France 11 Rue d'Arsonval 69680 Chassieu France Name and address of the manufacturer Same as applicant Name and address of the factory See page 2 Note: When more than one factory, please report on page 2 Ratings and principal characteristics Ue = 220V / 440V / 500V / 690V; Ie = 17A - 105A Iq = 80kA (690V, 3-pole) or 100 kA (220-440 / 500V) Ui = 690V; Uimp=6kVTrademark (if any) ABB Customer's Testing Facility (CTF) Stage used AF*40-30-**-**, AF*52-30-**-**, AF*65-30-**-**, AF*40-40-**-**, AF*40-22-**-**, AF*52-40-**-** Model / Type Ref. Additional information (if necessary may also be See page 2-3 reported on page 2) A sample of the product was tested and found IEC 60947-4-1:2018 to be in conformity with As shown in the Test Report Ref. No. which forms part 2110996STO-001 of this Certificate This CB Test Certificate is issued by the National Certification Body Intertek Semko AB **Torshamnsgatan 43** intertek **Box 1103** SE-164 22 Kista, Sweden Signature: Matha Date: 08 September, 2022 Leif Mattsson



Ref. Certif. No.

SE-108889A1

Factories

ABB France 11 Rue d'Arsonval 69680 Chassieu FRANCE

ABB Xinhui Low Voltage Switchgear Company Ltd Jinguzhou Ind. Development Zone Xinhui District, Jiangmen City Guangdong CN-529100 CHINA

Additional information

Ratings for AF-range of contactors covered by report:

Туре	AC-1:	AC-3:	AC-3:	AC-3:	AC-3e	Ac-3e	Ac-3e	AC-4:	AC-4:	AC-8a:
	690V	220- 440V	500V	690V	220- 440V	500V	690V	220- 500V	690V	400V
AF*40-30-**-** (I₀):	70	40	35	25	40	35	25	35*	25	53
AF*52-30-**-** (I₀):	100	53	45	35	56	45	35	45*	28	70
AF*65-30-**-** (I₀):	105	65	55	39	65	55	39	52*	31	85
AF*40-40-**-** (I₀):	70	40	35	25	-	-	-	35	25	-
AF*52-40-**-** (I₀):	100	53	45	35	-	-	-	45	28	-
AF*40-22-**-** (I₀):	70	40	35	25	-	-	-	35	17	-

*Also includes reversing starter contactor

This certificate replaces CB certificate SE-108889 dated 24 August 2022. A new certificate is issued due to editorial changes.

Date: 08 September, 2022

Signature: Mather

2/3



Ref. Certif. No.

SE-108889A1

Additional information

Type key for products covered by this report:

 $\frac{\text{AF}}{1} \stackrel{\text{S}}{\underline{2}} \frac{40}{3} - \frac{30}{4} - \frac{11}{5} - \frac{13}{6}$

1 = Main designation

AF Contactor AF Range

2 = Application

"blank": standard application S: contactor for safety applications

3 = Size of contactor

40, 52, 65

4 = Number of main contacts

30 = 3 NO- and 0 NC-contacts 22 = 2 NO- and 2 NC-contacts 40 = 4 NO- and 0 NC-contacts

5 = Number of auxiliary contacts

00 = 0 NO- and 0 NC-contacts 04 = 0 NO- and 4 NC-contacts. Mounted as 2nd stack, (only for AFS) 11 = 1 NO- and 1 NC-contacts. Side-mounting 13 = 1 NO- and 3 NC-contacts. Mounted as 2nd stack, (only for AFS) 22 = 2 NO- and 2 NC-contacts. Mounted as 2nd stack, (also for AFS) 31 = 3 NO- and 1 NC-contacts. Mounted as 2nd stack, (only for AFS)

6 = Coil configuration

11 = 20-60VDC/24-60VAC 12 = 48-130VAC/VDC 13 = 100-250VAC/VDC 14 = 250-500VAC/VDC 41 = 24-60VAC

Date: 08 September, 2022

Signature: Mathin