



中国国家强制性产品认证证书

证书编号: 2018010304059154

委托人名称、地址

ABB France
2 rue d'Arsonval 69680 Chassieu France

生产者(制造商)名称、地址

ABB France
2 rue d'Arsonval 69680 Chassieu France

生产企业名称、地址

ABB Bulgaria EOOD - Rakovski branch
BULGARIA, 4142 Village of Stryama, Region of Plovdiv, Municipality of
Rakovski, Rakovski Industrial Zone, 14 Industrial Road 1, nr, 14-18

产品名称和系列、规格、型号

切换电容器接触器

UA16-30...RA: Uimp:8kV; Ui: 1000V; Ith: 30A; 使用类别: AC-6b; Ue/Qe: 220-240V/8kvar, 400-415V/12.5
kvar, 440V/15 kvar, 500-550V/18 kvar, 690V/22 kvar, Ie: 21A; Us: 24V50/60Hz, 110V 50Hz/110-120V
60Hz, 220-230V 50Hz/230-240V 60Hz, 380-400V 50Hz/400-415V 60Hz; IP20; 极数: 3P; 配用的辅助触头:
(本体); Ith: 16A; AC-15: Ue/Ie: 24-127V/6A, 220-240V/4A, 380-440V/3A, 500-690V/2A;
DC-13: Ue/Ie: 24V/6A, 48V/2.8A, 72V/1A, 110-125V/0.55A, 220-250V/0.3A; 1NO; 型号解释见附件

产品标准和技术要求

GB/T 14048.4-2010

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求,
特发此证。

发证日期: 2020 年 08 月 07 日有效期至: 2023 年 03 月 30 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2018 年 03 月 30 日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询

经中国合格评定国家认可委员会认可 CNAS C001-P



主任:

陆楠



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2018010304059154

NAME AND ADDRESS OF THE APPLICANT

ABB France

2 rue d'Arsonval 69680 Chassieu France

NAME AND ADDRESS OF THE MANUFACTURER

ABB France

2 rue d'Arsonval 69680 Chassieu France

NAME AND ADDRESS OF THE FACTORY

ABB Bulgaria EOOD – Rakovski branch

BULGARIA, 4142 Village of Stryama, Region of Plovdiv, Municipality of Rakovski, Rakovski Industrial Zone, 14 Industrial Road 1, nr.14-18

PRODUCT NAME, MODEL AND SPECIFICATION

Contactors for capacitor switching

UA16-30...RA: Uimp:8kV; Ui: 1000V; Ith: 30A; Utilization Category: AC-6b; Ue/Qe: 220-240V/8kvar,400-415V/12.5 kvar,,440V/15 kvar,500-550V/18 kvar,,690V/22 kvar, le:21A; Us: 24V50/60Hz,110V 50Hz/110-120 V 60Hz,220-230V 50Hz/230-240V 60Hz,380-400V 50Hz/400-415V 60Hz; IP20; Poles: 3P; Attached Auxiliary Contacts: Ith: 16A; AC-15:Ue/Ie:24-127V/6A,220-240V/4A,380-440V/3A,500-690V/2A; DC-13:Ue/Ie:24V/6A,48V/2.8A,72V/1A,110-125V/0.55A,220-250V/0.3A; 1NO

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.4-2010

This is to certify that the above mentioned product(s) complies with therequirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Aug.07,2020Valid until:Mar.30,2023

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Mar.30,2018

The certificate information is available through CNCA's website: www.cnca.gov.cn

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附 录

证书编号: 2018010304059154

第 1 页 共 1 页

纸 号: 2658797

型号解释:

UA	16	30	10	RA	
I	II	III	IV	V	VI

I - Main designation : UA

II - Range size

16

III - Main Pole Construction

30 - 3 Normally Opened and 0 Normally Closed main poles.

IV - Auxiliary Pole Construction

10 - One Normally opened auxiliary pole provided.

V - RA means with insertion of damping resistors

VI - Coil code

See table 1

注: 此附录与证书同时使用时有效。



主 任:

陆 楠



中国质量认证中心