



Ref. Certif. No.

CN54150

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

Pilot device

Name and address of the applicant

ABB Xinhui Low Voltage Switchgear Co.,Ltd.  
Jinguzhou Industrial Development Zone, Xinhui District,  
Jiangmen City, Guangdong Province, P.R.China

Name and address of the manufacturer

ABB Xinhui Low Voltage Switchgear Co.,Ltd.  
Jinguzhou Industrial Development Zone, Xinhui District,  
Jiangmen City, Guangdong Province, P.R.China

Name and address of the factory

ABB Xinhui Low Voltage Switchgear Co.,Ltd.  
Jinguzhou Industrial Development Zone, Xinhui District,  
Jiangmen City, Guangdong Province, P.R.China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Ui: 300V Uimp: 6kV;Ith:5A; AC-15: 120V/3A,240V/2A(contact: Ag);  
120V/1.5A, 240V/1A(contact: Cu/Ep. Ag); DC-13: 24V/0.3A, 125V/0.2A

Trademark / Brand (if any)

ABB

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

CE,CEP

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-5-5:1997;IEC 60947-5-5:1997/AMD1:2005;IEC 60947-5-5:1997/AMD2:2016

As shown in the Test Report Ref. No. which forms part of this Certificate

00901- CB2021CQC-096821

This CB Test Certificate is issued by the National Certification Body

## CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Jul.12,2021

Signature:

谢肇煦

Xie ZhaoXu



CB 0064786