



产品认证证书

证书编号: CQC2010010303438770

申请人名称及地址

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

制造商名称及地址

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

生产企业名称及地址

ABB Stotz-Kontakt GmbH (V054913)
Hauptstrasse 14-16, D-78132 Hornberg, Germany

产品名称和系列、规格、型号

继电器

CM-IWS.1x, CM-IWS.2x, CM-IWN.1x, CM-IWN.4x, CM-IWN.5x, CM-IWN.6x, CM-IVN.x: Ui:300V;
Uimp:6kV; Ith:4A; AC-15: Ue/Ie:230V/3.0A; DC-13: Ue/Ie:24V/2.0A; IP20; 型号解释见附件

产品标准和技术要求

GB/T 14048.5-2017

认证模式

型式试验+获证后监督

上述产品符合 CQC11-462142-2019 认证规则的要求, 特发此证。

发证日期: 2020 年 09 月 02 日 有效期至: 2024 年 12 月 10 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

经中国合格评定国家认可委员会认可 CNAS C001-P

主任:

陆楠



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

C 0334132



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2010010303438770

NAME AND ADDRESS OF THE APPLICANT

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

NAME AND ADDRESS OF THE MANUFACTURER

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

NAME AND ADDRESS OF THE FACTORY

ABB Stotz-Kontakt GmbH (V054913)
Hauptstrasse 14-16, D-78132 Hornberg, Germany

PRODUCT NAME, MODEL AND SPECIFICATION

Relay

CM-IWS.1x, CM-IWS.2x, CM-IWN.1x, CM-IWN.4x, CM-IWN.5x, CM-IWN.6x, CM-IVN.x: Ui:300V;
Uimp:6kV; Ith:4A; AC-15: Ue/Ie:230V/3.0A; DC-13: Ue/Ie:24V/2.0A; IP20

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.5-2017

TYPE OF CERTIFICATION SCHEMES

Type testing+Follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462142-2019 .

Valid from: Sep.02,2020

Valid until: Dec.10,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

C 0334132



产品认证证书

附录

第 1 页 共 1 页

证书编号: CQC2010010303438770

纸号: 334132

型号解释:

CM-
I

IW
II

N
III

1
IV

S
V

I	Series / Type 系列	CM-	Electronic measuring and monitoring relays 电子测量与监视继电器
II	Variant 种类	IW	Insulation monitoring relay for IT-Supply-Systems IT 供电系统绝缘监视
		IV	Coupling Unit for voltage extension 电压耦合模块
III	Size 尺寸	S	22.5mm width 22.5mm 宽度
		N	45.0mm width 45mm 宽度
IV	System voltage / System capacitance 系统电压/ 系统对 地泄漏电容	1	AC / DC Systems AC/DC 系统; max. 10 μ F (S Size) / max. 20 μ F (N Size)
		2	AC Systems AC 系统; max. 10 μ F
		4	AC / DC Systems AC/DC 系统; max. 500 μ F
		5	AC / DC Systems AC/DC 系统; max. 1000 μ F
		6	AC / DC Systems AC/DC 系统; max. 2000 μ F
		blank	for CM-IVN
V	Terminal connection 接线端子形式	S	Screw-type terminal (new housing) 螺钉连接端子 (新外壳)
		P	Push-in-spring-force terminal (new housing) 插入式弹簧连接端子 (新外壳)
		blank	Screw-type terminal (old housing) 螺钉连接端子 (旧外壳)

注: 此附录与证书同时使用时有效。

主任:

陆梅

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

