

# 产品认证证书

## II型自愿认证

证书编号: CQC2010010304402983

发证日期: 2021年10月09日

有效期至: 2031年10月09日

委托人名称 ABB France  
及注册地址 11 Rue d' Arsonval 69680, Chassieu, FRANCE

制造商名称 ABB 新会低压开关有限公司  
及注册地址 广东省江门市新会区今古洲工业开发区

生产企业名称 ABB 新会低压开关有限公司  
及生产地址 广东省江门市新会区今古洲工业开发区

产品名称和系列、规格、型号 接触器  
AF50,AF63,AF75; 规格参数详见附件

产品标准和技术要求 GB/T 14048.4-2020

认证模式 产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

本证书为变更证书, 证书首次颁发日期: 2020年08月14日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 ( www.cnca.gov.cn ) 查验证书信息



授权签字人

签发

刘江

谢肇熙



中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0110797

# CERTIFICATE OF PRODUCT CERTIFICATION

## TYPE II CQC CERTIFICATION

**CERTIFICATE NO.:** CQC2010010304402983

**Valid from:** Oct.09,2021

**Valid until:** Oct.09,2031

|                                                                  |                                                                                                                                                     |
|------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>NAME AND REGISTERED ADDRESS OF THE APPLICANT</b>              | ABB France<br>11 Rue d' Arsonval 69680, Chassieu, FRANCE                                                                                            |
| <b>NAME AND REGISTERED ADDRESS OF THE MANUFACTURER</b>           | ABB Xinhui Low Voltage Switchgear Co.,Ltd.<br>Jinguzhou Industrial Development Zone, Xinhui District, Jiangmen City, Guangdong Province, P.R.China  |
| <b>NAME AND LOCATION OF THE FACTORY</b>                          | ABB Xinhui Low Voltage Switchgear Co., Ltd.<br>Jinguzhou Industrial Development Zone, Xinhui District, Jiangmen City, Guangdong Province, P.R.China |
| <b>PRODUCT NAME, MODEL AND SPECIFICATION</b>                     | Contactor<br>AF50,AF63,AF75; See the Appendix                                                                                                       |
| <b>THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS</b> | GB/T 14048.4-2020                                                                                                                                   |
| <b>TYPE OF CERTIFICATION SCHEMES</b>                             | Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection                                                                 |

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

Date of original issued: Aug.14,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



SIGN BY

刘江

SIGNATURE

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86 10 83886666

C(2) 0110797

# 产品认证证书

## II型自愿认证

证书编号: CQC2010010304402983

第1页 共2页

本证书及附件应同时使用, 信息查验说明见证书页

纸号: 110797

上报参数:

AF50, AF63, AF75

Ui: 1000V;

Uimp: 8kV;

AF50:

Ith: 100A;

Ue/Ie: AC-3: 220-230-240V/53A, 380-400V/50A, 415V/50A, 440V/45A, 500V/45A, 690V/35A;

AC-8a: 400V/63A; AC-1: 690V/100A;

AF63:

Ith: 125A;

Ue/Ie: AC-3: 220-230-240/65A, 380-400V/65A,

415V/65A, 440V/65A, 500V/55A, 690V/43A,

AC-8a: 400V/85A; AC-1: 690V/115A;

AF75:

Ith: 125A;

Ue/Ie: AC-3: 220-230-240V/75A, 380-400V/75A, 415V/75A, 440V/70A, 500V/65A, 690V/46A;

AC-8a: 400V/95A; AC-1: 690V/125A;

Us: 48-130V 50/60Hz/DC, 100-250V 50/60Hz/DC, 20-60V DC;

IP: 20(线圈)/IP10 (主回路端子);

3P;

配用的辅助触头 (外置):

CAL5, 证书编号: CQC2004010305133985;

AC-15: Ue/Ie: 24-127V/6A, 220-240V/4A, 380-440V/3A, 500-690V/2A;

DC-13: Ue/Ie: 24V/6A, 48V/2.8A, 72V/1A, 110V/0.55A, 125V/0.55A, 220V/0.3A, 250V/0.3A;

1NO1NC



中国质量认证中心



# 产品认证证书

## II型自愿认证

证书编号: CQC2010010304402983

第 2 页 共 2 页

本证书及附件应同时使用, 信息查验说明见证书页

纸号: 110797

型号解释:

AF5030-1 1

附件种类数量: 空白或 00: 没有附加附件; 11: 附加一只附件 CAL5;

常闭主触点对数 0: 0 对常闭主触点

常开主触点对数 3: 3 对常开主触点

380V, AC3 应用类别下额定工作电流 : 50:50A, 63:65A, 75:75A,

系列名称: AF 系列接触器



中国质量认证中心

