



产品认证证书

证书编号: CQC2010010305398829

申请人名称及地址

ABB 新会低压开关有限公司
广东省江门市新会区今古洲工业开发区

制造商名称及地址

ABB 新会低压开关有限公司
广东省江门市新会区今古洲工业开发区

生产企业名称及地址

ABB 新会低压开关有限公司 (V005372)
广东省江门市新会区今古洲工业开发区

产品名称和系列、规格、型号

双电源自动转换开关

ATS-CB021 R 4P; Ui: 500V; Uimp: 6kV; Ith: 320A、400A、500A、630A; Ue: AC400V; Ie: 320A、400A、500A、630A; 使用类别: AC-33iB; Icm (峰值): 154kA(T5H)、105kA(T5S); Icn: 70kA(T5H)、50kA(T5S); 电器级别: CB 级; 转换方式: ATSE; 极数: 4P; 控制器 Uimp: 6kV 型号解释详见附件

产品标准和技术要求

GB/T 14048.11-2016

认证模式

型式试验+初始工厂检查+获证后监督

上述产品符合 CQC11-462143-2019 认证规则的要求, 特发此证。

发证日期: 2020 年 08 月 14 日 有效期至: 2024 年 08 月 09 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

主任:

陆梅



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

C 0346477



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2010010305398829

NAME AND ADDRESS OF THE APPLICANT

ABB Xinhui Low Voltage Switchgear Co.,Ltd.
Jinguzhou Industrial Development Zone, Xinhui District, Jiangmen City, Guangdong Province, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

ABB Xinhui Low Voltage Switchgear Co.,Ltd.
Jinguzhou Industrial Development Zone, Xinhui District, Jiangmen City, Guangdong Province, P.R.China

NAME AND ADDRESS OF THE FACTORY

ABB Xinhui Low Voltage Switchgear Co.,Ltd. (V005372)
Jinguzhou Industrial Development Zone, Xinhui District, Jiangmen City, Guangdong Province, P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION

Electrical Device for Automatic Transfer Switch

ATS□-CB021 R□ 4P; Ui: 500V; Uimp: 6kV; Ith: 320A、400A、500A、630A; Ue: AC400V; Ie: 320A、400A、500A、630A; Utilization Category: AC-33iB; Icm (Peak Value): 154kA(T5H)、105kA(T5S); Icn: 70kA(T5H)、50kA(T5S); ATSE
Class: CB; Transfer Mode: ATSE; Poles: 4P; Controller: Uimp: 6kV. See the Appendix for type explanation

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.11-2016

TYPE OF CERTIFICATION SCHEMES

Type testing of product + initial factory inspection + follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462143-2019 .

Valid from: Aug.14,2020

Valid until: Aug.09,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

President: _____

陆梅

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

C 0346477



产品认证证书

附 录

第 1 页 共 1 页

证书编号: CQC2010010305398829

纸 号: 346477

型号的解释:

ATS □ - CB 021 R□ 4P

① ② ③ ④ ⑤ ⑥

①双电源自动转换开关

②断路器壳架电流

630S: T5S630 (I e : 630A、500A)

400S: T5S400 (I e : 400A、320A)

630H: T5H630 (I e : 630A、500A)

400H: T5H400 (I e : 400A、320A)

③ATSE 等级

④控制器型号

021: ATS021 控制器

⑤额定工作电流

⑥极数:

4P: 4 极

注: 此附录与证书同时使用时有效。

主任:

陆杨



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>