



产品认证证书

证书编号: CQC2011010302496899

申请人名称及地址

ABB 新会低压开关有限公司
广东省江门市新会区今古洲工业开发区

制造商名称及地址

ABB 新会低压开关有限公司
广东省江门市新会区今古洲工业开发区

生产企业名称及地址

ABB 新会低压开关有限公司 (V005372)
广东省江门市新会区今古洲工业开发区

产品名称和系列、规格、型号

隔离开关

OT2000、OT2500、OTM2000、OTM2500: Uimp: 12kV;Ui: 1000V;Ue: AC415V(2P), AC500V(3P,4P), AC690V(3P,4P);Ith:
2000A(OT2000, OTM2000), 2500A(OT2500, OTM2500);Ie: 2000A(OT2000, OTM2000), 2500A(OT2500, OTM2500)Icw:
55kA/1s;Icm(峰值):176kA;使用类别: AC-21B, AC-22B;极数: 2P, 3P, 4P; 型号解释见附件

产品标准和技术要求

GB/T14048.3-2017

认证模式

型式试验+初始工厂检查+获证后监督

上述产品符合 CQC11-462141-2019 认证规则的要求, 特发此证。

发证日期: 2020 年 08 月 14 日 有效期至: 2021 年 07 月 13 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

主任:

陆梅



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

C 0346479



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2011010302496899

NAME AND ADDRESS OF THE APPLICANT

ABB Xinhui Low Voltage Switchgear Co.,Ltd.
Jinguzhou Industrial Development Zone, Xinhui District, Jiangmen City, Guangdong Province, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

ABB Xinhui Low Voltage Switchgear Co.,Ltd.
Jinguzhou Industrial Development Zone, Xinhui District, Jiangmen City, Guangdong Province, P.R.China

NAME AND ADDRESS OF THE FACTORY

ABB Xinhui Low Voltage Switchgear Co.,Ltd. (V005372)
Jinguzhou Industrial Development Zone, Xinhui District, Jiangmen City, Guangdong Province, P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION

Switch-disconnector

OT2000、OT2500、OTM2000、OTM2500: Uimp: 12kV;Ui: 1000V;Ue: AC415V(2P), AC500V(3P,4P), AC690V(3P,4P);Ith:
2000A(OT2000, OTM2000), 2500A(OT2500, OTM2500);Ie: 2000A(OT2000, OTM2000), 2500A(OT2500, OTM2500)Icw:
55kA/1s;Icm(Peak):176kA;Utilization Category: AC-21B, AC-22B;Poles: 2P, 3P, 4P

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.3-2017

TYPE OF CERTIFICATION SCHEMES

Type testing of product + initial factory inspection + follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462141-2019 .

Valid from: Aug.14,2020

Valid until: Jul.13,2021

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

President: _____

陆梅

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

C 0346479



产品认证证书

附录

第 1 页 共 1 页

证书编号: CQC2011010302496899

纸号: 346479

型号解释:

OT □ □ □ □ □
1 2 3 4 5 6

1、隔离开关: OT(不带电动操作机构型)、OTM(带电动操作机构型);

2、额定电流: 2000、2500

3、适用标准: E (适用 IEC 标准)

4、极数及位置识别码:

OT 型识别码: 02: 操作机构右边 2 极; 03: 操作机构右边 3 极; 04: 操作机构右边 4 极;

11: 操作机构左边 1 极, 右边 1 极; 12: 操作机构左边 1 极, 右边 2 极;

21: 操作机构左边 2 极, 右边 1 极; 13: 操作机构左边 1 极, 右边 3 极;

31: 操作机构左边 3 极, 右边 1 极; 22: 操作机构左边 2 极, 右边 2 极;

OTM 型识别码: 2: 操作机构右边 2 极; 3: 操作机构右边 3 极; 4: 操作机构右边 4 极

5、相间宽度: 空白 (基本型)、W4 (加宽相间 60mm)、W8 (加宽相间 120mm)

6、操作方式: P (配门板操作手柄及轴)、K (配直接操作手柄)、空白 (无操作手柄)

M230C (配交流电动操作机构)、M230V (配交直流电动操作机构)

注: 此附录与证书同时使用时有效。

主任:

陆梅



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>