产品认证证书

II型自愿认证

证书编号：CQC2013010304615753

发证日期：2020年08月21日

有效期至：2032年06月17日

委托人名称及注册地址	ABB France 2 rue d'Arsonval 69680 Chassieu France
制造商名称及注册地址	ABB France 2 rue d'Arsonval 69680 Chassieu France
生产企业名称及生产地址	ABB France 2 rue d'Arsonval 69680 Chassieu France
产品名称和系列、规格、型号	接触器 A9,A12,A16;详见附件
产品标准和技术要求	GB/T 14048.4-2010
认证模式	产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求，特发此证。

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站（www.cnca.gov.cn）查验证书信息

授权签字人 郑士泉　　签发 谢肇煦

中国质量认证中心

CHINA QUALITY CERTIFICATION CENTRE 中国质量认证中心

C(2) 0157706

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2013010304615753

Valid from: Aug.21,2020

Valid until: Jun.17,2032

NAME AND REGISTERED ADDRESS OF THE APPLICANT	ABB France 2 rue d'Arsonval 69680 Chassieu France
NAME AND REGISTERED ADDRESS OF THE MANUFACTURER	ABB France 2 rue d'Arsonval 69680 Chassieu France
NAME AND LOCATION OF THE FACTORY	ABB France 2 rue d'Arsonval 69680 Chassieu France
PRODUCT NAME, MODEL AND SPECIFICATION	Contactor A9,A12,A16;see the Appendix
THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS	GB/T 14048.4-2010
TYPE OF CERTIFICATION SCHEMES	Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn

SIGN BY 郑十泉

SIGNATURE 谢肇煦

CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE 中国质量认证中心

产品认证证书

II型自愿认证

附　　录

证书编号：CQC2013010304615753

纸　号：157706

A9，A12，A16

Ui：1000V;

A9：

Ith：26A;

AC-1：Ue/Ie：690V/25A;

AC-3：Ue/Ie：220-230-240V/9A, 380-400V/9A, 415V/9A, 440V/9A, 500V/9A, 690V/7A;

AC-8a：Ue/Ie：400V/12A;

A12：

Ith：28A;

AC-1：Ue/Ie：690V/27A;

AC-3：Ue/Ie：220-230-240V/12A, 380-400V/12A, 415V/12A, 440V/12A, 500V/12A, 690V/9A;

AC-8a：Ue/Ie：400V/16A;

A16：

Ith：30A;

AC-1：Ue/Ie：690V/30A;

AC-3：Ue/Ie：220-230-240V/17A, 380-400V/17A, 415V/17A, 440V/16A, 500V/14A, 690V/10A;

AC-8a：Ue/Ie：400V/22A;

Us：24V 50/60Hz, 48V 50/60Hz, 110V 50Hz/110-120V 60Hz,

注：此附录与证书同时使用时有效。

中国质量认证中心

产品认证证书

II型自愿认证

附　　录

证书编号：CQC2013010304615753

纸　号：157706

220-230V 50Hz/230-240V 60Hz, 380-400V 50Hz/400-415V 60Hz,
400-415 V 50Hz/415-440 V 60Hz;

3P，4P;

IP20;

配用辅助触头：(本体)

Ith：16A;

AC-15：Ue/Ie：24-127V/6A, 220-240V/4A, 380-440V/3A, 500-690V/2A;

DC-13：Ue/Ie：24V/6A, 48V/2.8A, 72V/2A, 110-125V/1.1A, 220-250V/0.55A;

无，1 NO　，1NC，1NO1NC，2NO2NC，3NO2NC

注：此附录与证书同时使用时有效。

中国质量认证中心