

产品认证证书

II型自愿认证

证书编号: CQC2015010308815239

发证日期: 2021 年 11 月 16 日

有效期至: 2031 年 08 月 30 日

委托人名称	ABB (中国) 有限公司
及注册地址	北京市朝阳区酒仙桥路 10 号恒通广厦
制造商名称	美尔森电气保护系统(上海)有限公司
及注册地址	上海市松江区书山路 55 弄 6、7、8 号
生产企业名称	美尔森电气系统(浙江)有限公司
及生产地址	浙江省湖州市长兴技术开发区陈王路 1228 号 2 号厂房
产品名称和系列、 规格、型号	低压熔断体(刀形触头熔断体) OFAFC0GG**-*; Un:AC690V/500V;In:6A,10A,16A,20A,25A,32A,35A,40A,50A,63A,80A,100A,125A,160A(690V/500V);200A(500V);I1:80kA(690V),120kA(500V);分断范围和使用类别:gG
产品标准和技术要求	GB/T 13539.2-2015
认证模式	产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

本证书为变更证书, 证书首次颁发日期: 2020 年 04 月 24 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



授权签字人

张明

签发

谢肇煦

中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0118419

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2015010308815239

Valid from: Nov.16,2021

Valid until: Aug.30,2031

NAME AND REGISTERED ADDRESS OF THE APPLICANT ABB (China) Co., Ltd.
Universal Plaza, No.10 Jiuxianqiao Road, Chaoyang District, Beijing 100016, P.R.China

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER Mersen Shanghai Co.,Ltd.
No.6,7,8, Lane 55, Shushan Road, Songjiang District, Shanghai City, P.R.China

NAME AND LOCATION OF THE FACTORY MERSEN ZHEJIANG CO., LTD.
Building 2#, No. 1228, Chenwang Road, Technical Development Zone, Changxing, Huzhou City, Zhejiang Province, P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION Low-voltage Fuse(Fuse-link with Knife Blade Contact)
OFAFC0GG**-*;
Un:AC690V/500V;In:6A,10A,16A,20A,25A,32A,35A,40A,50A,63A,80A,100A,125A,160A(690V/500V);200A(500V);I1:80kA(690V),120kA(500V);Breaking Range and Utilization Category:gG

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS GB/T 13539.2-2015

TYPE OF CERTIFICATION SCHEMES Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

Date of original issued: Apr.24,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

杨志刚

SIGNATURE

谢肇煦

CHINA QUALITY CERTIFICATION CENTRE

