

产品认证证书

II型自愿认证

证书编号: CQC2015010309791750

发证日期: 2022年03月30日

有效期至: 2032年03月29日

委托人名称 ABB Stotz-Kontakt GmbH
及注册地址 Eppelheimer Strasse 82 69123 Heidelberg Germany

制造商名称 ABB Stotz-Kontakt GmbH
及注册地址 Eppelheimer Strasse 82 69123 Heidelberg Germany

生产企业名称 ABB Stotz-Kontakt GmbH
及生产地址 Hauptstrasse 14-16, D-78132 Hornberg, Germany

产品名称和系列、规格、型号 电动机控制器
UMC100.3 UC, UMC100.3 DC; 详见参数附件

产品标准和技术要求 GB/T 14048.4-2020

认证模式 产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

本证书为变更证书, 证书首次颁发日期: 2020年10月10日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



授权签字人

签发

陈昕

谢肇煦



中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0147820

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2015010309791750

Valid from: Mar.30,2022

Valid until: Mar.29,2032

NAME AND REGISTERED ADDRESS OF THE APPLICANT ABB Stötz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER ABB Stötz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

NAME AND LOCATION OF THE FACTORY ABB Stötz-Kontakt GmbH
Hauptstrasse 14-16, D-78132 Hornberg, Germany

PRODUCT NAME, MODEL AND SPECIFICATION Motor Controller
UMC100.3 UC, UMC100.3 DC; See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS GB/T 14048.4-2020

TYPE OF CERTIFICATION SCHEMES Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

Date of original issued: Oct.10,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

陈昕

SIGNATURE

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86 10 83886666

C(2) 0147820

产品认证证书

II型自愿认证

证书编号: CQC2015010309791750

第1页 共1页

本证书及附件应同时使用, 信息查验说明见证书页

纸号: 147820

UMC100.3 UC, UMC100.3 DC

Uimp: 8kV;

Ui: 690V;

Ue: 690V / 1000V with insulated wires ;

Ie: 0.24-63A;

脱扣级别: 5E, 10E, 20E, 30E, 40E;

极数: 3P; IP20;

配用辅助触头: (本体)

3NO

Ith: 5A;

AC-15: Ue/Ie: 240V/1.5A, 120V/3A;

DC-13: Ue/Ie: 24V/1A, 125V/0.22A, 250V/0.11A

型号解释:

UMC100.3 UC
1 2

1: Product name

2: UC : 110 – 240V AC/DC

DC : 24V DC



中国质量认证中心

