

产品认证证书

II型自愿认证

证书编号: CQC2016010307930423

发证日期: 2022年01月13日

有效期至: 2032年01月13日

委托人名称
及注册地址 ABB Switzerland Ltd, Low Voltage Products
Fulachstrasse 150, CH-8201 Schaffhausen, Switzerland

制造商名称
及注册地址 ABB Switzerland Ltd, Low Voltage Products
Fulachstrasse 150, CH-8201 Schaffhausen, Switzerland

生产企业名称
及生产地址 ABB Switzerland Ltd, Low Voltage Products
Fulachstrasse 150, CH-8201 Schaffhausen, Switzerland

产品名称和系列、
规格、型号 剩余电流动作断路器
FS401E, FS401M, FS401MK; Ue:AC240V;In:6A,10A,13A,16A,20A,25A,32A;瞬时脱扣类
型:B型,C型;Ics:6kA(E),7.5kA(M,MK);Icn:6kA(E),10kA(M,MK);IΔn:30mA;额定剩余动作类
型:A型,电磁式;IΔm: 6kA(E),10kA(M,MK);极数:2P;型号解释详见附件

产品标准和技术要求 GB/T 16917.1-2014;GB/T 16917.21-2008

认证模式 产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

本证书为变更证书, 证书首次颁发日期: 2020年08月28日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



授权签字人

签发

陈昕

谢肇熙



中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0131265

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2016010307930423

Valid from: Jan.13,2022

Valid until: Jan.13,2032

NAME AND REGISTERED ADDRESS OF THE APPLICANT ABB Switzerland Ltd, Low Voltage Products
Fulachstrasse 150, CH-8201 Schaffhausen, Switzerland

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER ABB Switzerland Ltd, Low Voltage Products
Fulachstrasse 150, CH-8201 Schaffhausen, Switzerland

NAME AND LOCATION OF THE FACTORY ABB Switzerland Ltd, Low Voltage Products
Fulachstrasse 150, CH-8201 Schaffhausen, Switzerland

PRODUCT NAME, MODEL AND SPECIFICATION RCBO
FS401E, FS401M, FS401MK; Ue:AC240V;In:6A,10A,13A,16A,20A,25A,32A;Type of Instantaneous Tripping Current:B,C;Ics:6kA(E),7.5kA(M,MK);Icn:6kA(E),10kA(M,MK);IΔn:30mA Rated Residual Operating Type:A 型,Electromagnetic Hydraulic;IΔm:6kA(E),10 kA(M,MK);Poles:2P;See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS GB/T 16917.1-2014;GB/T 16917.21-2008

TYPE OF CERTIFICATION SCHEMES Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

Date of original issued: Aug.28,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

陈昕

SIGNATURE

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86 10 83886666

C(2) 0131265

产品认证证书

II型自愿认证

附 录

证书编号: CQC2016010307930423

第 1 页 共 2 页

纸 号: 131265

型号解释:

FS4 ☐ ☐ ☐ ☐ / ☐
1 2 3 4 5 6

1. FS4 Series

2. Method of fixing

0 = snap on (smisline system, Socket System)

3. Number of poles

1 = 1+N (AC 240 V)

4. Rated making and breaking cap.

M = 10 kA

MK = 10 kA (short time delay)

E = 6 kA

5. Tripping characteristic : B, C

注: 此附录与证书同时使用时有效。



中国质量认证中心



产品认证证书

II型自愿认证

附 录

证书编号: CQC2016010307930423

第 2 页 共 2 页

纸 号: 131265

6. Rated current: 6, 10, 13, 16, 20, 25, 32 A
7. Rated residual operating current: 0.03



注: 此附录与证书同时使用时有效。



中国质量认证中心

