

产品认证证书

II型自愿认证

证书编号: CQC2019010307189186

发证日期: 2021年08月06日

有效期至: 2031年08月06日

委托人名称	ABB S.p.A.
及注册地址	Via Vittor Pisani 16-20124 Milano (MI)-Italy
制造商名称	ABB S.p.A.
及注册地址	Viale dell'Industria 18-20010 Vittuone (MI)-Italy
生产企业名称	ABB S.p.A.
及生产地址	Via Ardeatina 2491-00040 Santa Palomba (RM) - Italy
产品名称和系列、 规格、型号	剩余电流动作断路器 DS201 :Uimp: 4kV;Ui: 500V;Ue: 230V;In: 2A,4A,6A,8A,10A,13A,16A,20A,25A,32A,40A; 瞬时脱扣类型 :B, C 型;I _{Δn} :10 mA, 30 mA, 100mA,300mA;额定剩余动作类型 : A , AC , AP-R , 电磁式;I _{Δm} : 4500 A (32A,40A),6000A(2A,4A,6A,8A,10A,13A,16A,20A,25A);Ics:6000A;Icn: 6000A;极数: 1P+N;适用于隔离;适用频率: 50/60Hz ; 型号解释见附件
产品标准和技术要求	GB/T 16917.1-2014;GB/T 16917.21-2008
认证模式	产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

本证书为变更证书, 证书首次颁发日期: 2020年08月28日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



授权签字人

陈昕

签发

谢肇煦

中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0082103

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2019010307189186

Valid from: Aug.06,2021

Valid until: Aug.06,2031

NAME AND REGISTERED ADDRESS OF THE APPLICANT ABB S.p.A.
Via Vittor Pisani 16-20124 Milano (MI)-Italy

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER ABB S.p.A.
Viale dell'Industria 18-20010 Vittuone (MI)-Italy

NAME AND LOCATION OF THE FACTORY ABB S.p.A.
Via Ardeatina 2491-00040 Santa Palomba (RM) - Italy

PRODUCT NAME, MODEL AND SPECIFICATION Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBO's)
DS201 : Uimp: 4kV;Ui: 500V;Ue: 230V;In: 2A,4A,6A,8A,10A,13A,16A,20A,25A,32A,40A;Type B,C;I_{Δn} : 10 mA, 30 mA, 100mA,300mA;Type A , AC , AP-R , Electromagnetic ;I_{Δm} : 4500 A (32A,40A),6000A(2A,4A,6A,8A,10A,13A,16A,20A,25A);Ics:6000A;Icn: 6000A;Poles: 1P+N;Suitable for isolation ; Applicable frequency : 50/60Hz

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS GB/T 16917.1-2014;GB/T 16917.21-2008

TYPE OF CERTIFICATION SCHEMES Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.
Date of original issued: Aug.28,2020
The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

陈昕

SIGNATURE

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86 10 83886666

C(2) 0082103

产品认证证书

II型自愿认证

附 录

证书编号: CQC2019010307189186

第 1 页 共 1 页

纸 号: 82103

型号解释:

DS 201	C	16	0.03	A
1	2	3	4	5

1——Series DS201 系列

2——Instantaneous tripping current 瞬时脱扣特性:

B - B Characteristic 特性

C - C Characteristic 特性

3——Rated current 额定电流:

2A; 4A; 6 A; 8A; 10A; 13A; 16 A; 20A; 25A; 32A; 40A

4——Rated residual current 额定剩余动作电流 $I_{\Delta n}$

0,01 A; 0,03 A; 0.1A; 0,3 A;

5——Operating characteristic 剩余电流动作特性:

AC- AC型; A- A 型; AP-R - AP-R 型

注: 此附录与证书同时使用时有效。



中国质量认证中心

