



中国国家强制性产品认证证书

证书编号: 2002010304007860

委托人名称、地址

ABB AB, Control Products
Motorgrand 20, 72161 Vasteras, Sweden

生产者(制造商)名称、地址

ABB AB, Control Products
Motorgrand 20, 72161 Vasteras, Sweden

生产企业名称、地址

ABB AB, Control Products
Motorgrand 20, 72161 Vasteras, Sweden

产品名称和系列、规格、型号

接触器

AF95,AF95...RT,AF95B...RT,AF110,AF110...RT,AF110B...RT;详见参数附件

产品标准和技术要求

GB/T14048.4-2010

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求,
特发此证。

发证日期: 2020 年 04 月 09 日 有效期至: 2024 年 12 月 10 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2002 年 07 月 16 日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询
经中国合格评定国家认可委员会认可 CNAS C001-P



主 任:

陆楠



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2002010304007860

NAME AND ADDRESS OF THE APPLICANT

ABB AB, Control Products
Motorgrand 20, 72161 Vasteras, Sweden

NAME AND ADDRESS OF THE MANUFACTURER

ABB AB, Control Products
Motorgrand 20, 72161 Vasteras, Sweden

NAME AND ADDRESS OF THE FACTORY

ABB AB, Control Products
Motorgrand 20, 72161 Vasteras, Sweden

PRODUCT NAME, MODEL AND SPECIFICATION

Contactor
AF95,AF95...RT,AF95B...RT,AF110,AF110...RT,AF110B...RT;See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.4-2010

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Apr.09,2020

Valid until: Dec.10,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Jul.16,2002

The certificate information is available through CNCA's website: www.cnca.gov.cn
Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附录:

第 1 页 共 2 页

证书编号: 2002010304007860

纸号: 2536706

AF95, AF95...RT, AF95B...RT, AF110, AF110...RT, AF110B...RT
Ui: 1000V;

AF95, AF95...RT, AF95B...RT: Ith: 145A;

AC-1: Ue/Ie: 415/690/1000V/145A;

AC-3: Ue/Ie: 220-240-380-400-415V/96A, 660-690V/65A, 1000V/30A;

AF110, AF110...RT, AF110B...RT: Ith: 160A;

AC-1: Ue/Ie: 415/690/1000V/160A;

AC-3: Ue/Ie: 220-240-380-400-415V/110A, 660-690V/82A, 1000V/30A;

Us: 48-130V AC/DC, 100-250V AC/DC;

极数: 3P;

配用辅助触头: CAL18-11, CAL18-11B, CAL18-11RT

1NO1NC

Ith: 16A;

AC-15: Ue/Ie: 24-127V/6A, 220-240V/4A, 280-440V/3A, 500-690V/2A;

DC-13: Ue/Ie: 24V/6A, 48V/2.8A, 72V/1A, 125V/0.55A, 250V/0.3A

注: 此附录与证书同时使用时有效。



主任:

陆杨



中国质量认证中心



中国国家强制性产品认证证书

附录:

第 2 页 共 2 页

证书编号: 2002010304007860

纸号: 2536706

型号的解释(Explanation of model/ type):

AF	110	B	-	30	-	11	RT
1	2	3		4		5	6

1. Product series code
 2. Size code
 3. B = smoke & fire approval, blank= normal product
 4. Main contacts: NO& NC quantity 30: 3 NO+ 0 NC.
 5. Auxiliary contacts: NO&NC quantity 11: 1NO+1NC
- RT: Ring Terminals blank: normal terminals

注: 此附录与证书同时使用时有效。



主 任:

陆梅



中国质量认证中心