

CERTIFICATE OF COMPLIANCE

Certificate Number 20150602-E73397
Report Reference E73397-20150529
Issue Date 2015-JUNE-02

Issued to: ABB AB, Control Products
Motorgrand 20
SE-721 61 Vasteras SWEDEN

This is to certify that representative samples of COMPONENT - SWITCHES, INDUSTRIAL CONTROL
"See Addendum Page"

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 60947-4-1 - Low-Voltage Switchgear and Controlgear – Part 1: Contactors and motor-starters – Electromechanical contactors and motor-starters
CAN/CSA C22.2 No. 60947-4-1-07

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Recognized components are incomplete in certain constructional features or restricted in performance capabilities and are intended for use as components of complete equipment submitted for investigation rather than for direct separate installation in the field. The final acceptance of the component is dependent upon its installation and use in complete equipment submitted to UL LLC.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20150602-E73397
Report Reference E73397-20150529
Issue Date 2015-JUNE-02

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Open type, Industrial control switches, Type AF116B or AF140B followed by -40, followed by -22, followed by RT, followed by additional suffixes indicating coil voltage.


May be used with USL,CNL - Accessories for AF116-40 or AF140-40 Contactors:

Terminal shroud Type. LT140-40L

Connection devices LL140-40, LD140-40

Aux. contact blocks Type. CAL19-11-RT, CAL19-11B-RT, CEL19-10-RT, CEL19-01-RT

Mechanical interlocks Type. VM19 and VM140/190



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>

