

Page 1 of 3

Certificate No: LR2002421TA Issue Date: 22/10/2020 Expiry Date: 16/02/2025

Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

Manufacturer ABB Electrification Sweden AB

Address Motorgränd 20, Västeras, 72161, Sweden

Place of Production ABB Xinhui Low Voltage Switchgear Co., Ltd.

Jinguzhou Industrial Development Zone, Xinhui Dist., Jiangmen, 529100, China

Place of Production ABB Electrification Sweden AB

Motorgränd 20, Västeras, 72161, Sweden

Type Contactors

Description Three and four pole contactors AF-series

Types:

AF116-30 / AF116-40 AF140-30 / AF140-40

AF146-30

AF190-30 / AF190-40 AF205-30 / AF205-40 AF265-30 / AF265-40 AF305-30 / AF305-40 AF370-30 / AF370-40

Trade Name AF116, AF140, AF146, AF190, AF205, AF265, AF305, AF370

Thorsten Wolff

Senior Specialist to Lloyd's Register EMEA A member of the Lloyd's Register group

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.



Page 2 of 3

Certificate No: LR2002421TA Issue Date: 22/10/2020 Expiry Date: 16/02/2025

Type Approval Certificate

Application Marine and offshore applications in category ENV1, ENV2 and ENV3 as defined

in Lloyd's Register's Type Approval System, Test Specification Number 1 – 2013.

Specified Standard Manufacturer's specification

IACS E10 Rev. 7 - 2018

Ratings AF116-30 to AF370-30

Rated operational voltage (Ue): 440 - 1000 V

Rated Frequency: 50/60 Hz

Rated operational current AC-1 (le): 160 - 600 A ($690 \text{ V} / 40 ^{\circ}\text{C}$) Rated operational current AC-3 (le): 116 - 370 A ($440 \text{ V} / 60 ^{\circ}\text{C}$)

AF116-40 to AF370-40

Rated operational voltage (Ue): 440 - 1000 V

Rated Frequency: 50/60 Hz

Rated operational current AC-1 (le): 160 - 525 A (690 V / 40 °C) Rated operational current AC-3 (le): 116 - 370 A (440 V / 60 °C)

Software version PLC-Control: 2.1.x

For detailed ratings, pls. refer to appendix.

Additional Tests Low temperature test: -15 °C / 16 h (AFxxx-30 only)

Low temperature test: -25 °C / 16 h (for AF116-30, AF190-30, AF265-30)

Other Conditions Manufacturer's derating table is to be observed.

Ventilation arrangement is to be arranged as per manufacturer's instructions.

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.



Page 3 of 3

Certificate No: LR2002421TA Issue Date: 22/10/2020 Expiry Date: 16/02/2025

Type Approval Certificate

This certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid Certificate.

The Design Appraisal Document No. HTS/ETS 40456-20/MK/TW and its supplementary Type Approval Terms and Conditions form part of this Certificate.

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.



Page 1 of 2

Certificate No: LR2002421TA Issue Date: 22/10/2020 Expiry Date: 16/02/2025

Appendix

DESCRIPTION

Three und four pole contractors

Types: AF116-30, AF116-40

AF140-30, AF140-40

AF146-30

AF190-30, AF190-40 AF205-30, AF205-40 AF265-30, AF265-40 AF305-30, AF305-40 AF370-30, AF370-40

RATINGS

Rated making capacity AC-3: 10 x le AC-3 acc. to IEC 60947-4-1 Rated breaking capacity AC-3: 8 x le AC-3 acc. to IEC 60947-4-1

Supply voltage codes: Code 11: Us = 24-60 V AC / 20-60 VDC

Code 12: Us = 48-130 V AC / DC Code 13: Us = 100-250 V AC / DC Code 14: Us = 250-500 V AC / DC

Code 31: Us = 24-60 V AC / 20-60 VDC (PLC-control) Code 32: Us = 48-130 V AC / DC (PLC-control) Code 33: Us = 100-250 V AC / DC (PLC-control) Code 34: Us = 250-500 V AC / DC (PLC-control)

AF116 ... AF370 3-pole contactors

Utilization	le	Ambient		
[V]	[A]	temperature		
		[°C]		
AF116-30				
AC-3: 1000	1	-		
AC-3: 690	65	60		
AC-3: 440	116	60		
AC-1: 690	160	40		
AF140-30				
AC-3: 1000	ı	1		
AC-3: 690	80	60		
AC-3: 440	140	60		
AC-1: 690	200	40		
AF146-30				
AC-3: 1000	60	60		
AC-3: 690	93	60		
AC-3: 440	146	60		
AC-1: 1000	225	40		

AF116 ... AF370 4-pole contactors

ALTTO AL210	AF116 AF370 4-pole contactors				
Utilization	le	Ambient			
[V]	[A]	temperature			
		[°C]			
AF116-40					
AC-3: 1000	-	-			
AC-3: 690	-	-			
AC-3: 440	116	60			
AC-1: 690	145	60			
AC-1: 690	160	40			
AF140-40					
AC-3: 1000	-	-			
AC-3: 690	-	-			
AC-3: 440	140	60			
AC-1: 690	175	60			
AC-1: 690	200	40			

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

R R

> IX IX IX

K R R

R R R

R R

IR

IR



Page 2 of 2

Certificate No: LR2002421TA Issue Date: 22/10/2020 Expiry Date: 16/02/2025

RATINGS (continued)

AF116 AF370 3-pole contactors				
Utilization	le	Ambient		
[V]	[A]	temperature		
		[°C]		
AF190-30				
AC-3: 1000	85	60		
AC-3: 690	135	60		
AC-3: 440	190	60		
AC-1: 1000	250	40		
AC-1: 690	275	40		
AF205-30				
AC-3: 1000	100	60		
AC-3: 690	165	60		
AC-3: 440	205	60		
AC-1: 1000	275	40		
AC-1: 690	350	40		
AF265-30	•			
AC-3: 1000	113	60		
AC-3: 690	250	60		
AC-3: 440	265	60		
AC-1: 1000	350	40		
AC-1: 690	400	40		
AF305-30	•			
AC-3: 1000	131	60		
AC-3: 690	290	60		
AC-3: 440	305	60		
AC-1: 1000	375	40		
AC-1: 690	500	40		
AF370-30	1			
AC-3: 1000	141	60		
AC-3: 690	315	60		
AC-3: 440	370	60		
AC-1: 1000	400	40		
AC-1: 690	600	40		

AF116 ... AF370 4-pole contactors

AF116 AF370 4-pole contactors					
Utilization	le	Ambient			
[V]	[A]	temperature			
		[°C]			
	AF190-40				
AC-3: 1000		-			
AC-3: 690	-	-			
AC-3: 440	190	60			
AC-1: 1000	250	40			
AC-1: 690	250	60			
AC-1: 690	275	40			
AF205-40	AF205-40				
AC-3: 1000	-	-			
AC-3: 690	-				
AC-3: 440	205	60			
AC-1: 1000	275	40			
AC-1: 690	300	60			
AC-1: 690	350	40			
AF265-40					
AC-3: 1000	-	-			
AC-3: 690	-	-			
AC-3: 440	265	60			
AC-1: 1000	350	40			
AC-1: 690	350	60			
AC-1: 690	400	40			
AF305-40					
AC-3: 1000	-	-			
AC-3: 690	-	-			
AC-3: 440	305	60			
AC-1: 1000	375	40			
AC-1: 690	400	60			
AC-1: 690	500	40			
AF370-40					
AC-3: 1000	-	-			
AC-3: 690	-	-			
AC-3: 440	370	60			
AC-1: 1000	400	40			
AC-1: 690	425	60			
AC-1: 690	525	40			

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

R R

> R R R R R