

TYPE APPROVAL CERTIFICATE

Certificate No:
TAE00001W1
Revision No:
1

This is to certify:

That the Contactor

with type designation(s)
AF400 to AF2850,

Issued to

ABB Electrification Sweden AB, Motor Starting & Safety
Västerås, Sweden

is found to comply with

DNV rules for classification – Ships, offshore units, and high speed and light craft

Application :

For installations inside switchboards / enclosures onboard ships and offshore units

Products approved by this certificate are accepted for installation on all vessels classed by DNV.

| Type | Rated voltage (V) | Rated current (A) | Frequency (Hz) |
|-----------------|-------------------|--------------------------|----------------|
| AF400 to AF2850 | 220 - 1000 | 600 - 2850 (1000 V/ AC1) | 50 / 60 |

Issued at **Høvik** on **2022-12-21**

for **DNV**

This Certificate is valid until **2027-05-14**.

DNV local unit: **Sweden CMC**

Approval Engineer: **Nicolay Horn**

Frederik Tore Elter
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Name and place of manufacturer

| | |
|--|--|
| ABB AB, Electrification Sweden AB, Motor Starting & Safety VÄSTERÅS, Sweden | ABB Xinhui Low Voltage Switchgear Co, Ltd Xinhui, China |
| ABB India Limited, Bangalore Karnataka, India | |

Product description

| Contactor type | | AF400-30 | | | |
|--------------------------------|----|----------|-----|-----|------|
| Rated insulation voltage (Ui) | V | 1000 | | | |
| Rated Frequency | Hz | 50/60 | | | |
| Rated thermal current (Ith) | A | 600 | | | |
| Utilization category | | AC-3 | | | AC-1 |
| Ambient temperature | °C | 55 | 55 | 55 | 40 |
| Rated operational voltage (Ue) | V | 1000 | 690 | 500 | 1000 |
| Rated operational current (Ie) | A | 155 | 350 | 400 | 600 |

| Contactor type | | AF460-30 | | | |
|--------------------------------|----|----------|-----|-----|------|
| Rated insulation voltage (Ui) | V | 1000 | | | |
| Rated Frequency | Hz | 50/60 | | | |
| Rated thermal current (Ith) | A | 700 | | | |
| Utilization category | | AC-3 | | | AC-1 |
| Ambient temperature | °C | 55 | 55 | 55 | 40 |
| Rated operational voltage (Ue) | V | 1000 | 690 | 500 | 1000 |
| Rated operational current (Ie) | A | 200 | 400 | 460 | 700 |

| Contactor type | | AF580-30 | | | |
|--------------------------------|----|----------|-----|-----|------|
| Rated insulation voltage (Ui) | V | 1000 | | | |
| Rated Frequency | Hz | 50/60 | | | |
| Rated thermal current (Ith) | A | 800 | | | |
| Utilization category | | AC-3 | | | AC-1 |
| Ambient temperature | °C | 55 | 55 | 55 | 40 |
| Rated operational voltage (Ue) | V | 1000 | 690 | 500 | 1000 |
| Rated operational current (Ie) | A | 250 | 500 | 580 | 800 |

| Contactor type | | AF750-30 | | | |
|--------------------------------|----|----------|-----|-----|------|
| Rated insulation voltage (Ui) | V | 1000 | | | |
| Rated Frequency | Hz | 50/60 | | | |
| Rated thermal current (Ith) | A | 1050 | | | |
| Utilization category | | AC-3 | | | AC-1 |
| Ambient temperature | °C | 55 | 55 | 55 | 40 |
| Rated operational voltage (Ue) | V | 1000 | 690 | 500 | 1000 |
| Rated operational current (Ie) | A | 300 | 650 | 750 | 1050 |

| Contactor type | | AF1250-30 | | | |
|--------------------------------|----|-----------|---|-----|------|
| Rated insulation voltage (Ui) | V | 1000 | | | |
| Rated Frequency | Hz | 50/60 | | | |
| Rated thermal current (Ith) | A | 1260 | | | |
| Utilization category | | AC-3 | | | AC-1 |
| Ambient temperature | °C | - | - | 55 | 40 |
| Rated operational voltage (Ue) | V | - | - | 440 | 1000 |
| Rated operational current (Ie) | A | - | - | 800 | 1260 |

| Contactor type | | AF1350-30 | | | |
|--------------------------------|----|-----------|-----|-----|------|
| Rated insulation voltage (Ui) | V | 1000 | | | |
| Rated Frequency | Hz | 50/60 | | | |
| Rated thermal current (Ith) | A | 1350 | | | |
| Utilization category | | AC-3 | | | AC-1 |
| Ambient temperature | °C | 55 | 55 | 55 | 40 |
| Rated operational voltage (Ue) | V | 1000 | 690 | 440 | 1000 |
| Rated operational current (Ie) | A | 375 | 800 | 860 | 1350 |

| Contactor type | | AF1650-30 | | | |
|--------------------------------|----|-----------|-----|------|------|
| Rated insulation voltage (Ui) | V | 1000 | | | |
| Rated Frequency | Hz | 50/60 | | | |
| Rated thermal current (Ith) | A | 1650 | | | |
| Utilization category | | AC-3 | | | AC-1 |
| Ambient temperature | °C | 55 | 55 | 55 | 40 |
| Rated operational voltage (Ue) | V | 1000 | 690 | 440 | 1000 |
| Rated operational current (Ie) | A | 400 | 970 | 1060 | 1650 |

| Contactor type | | AF2050-30 | | | |
|--------------------------------|----|-----------|-----|-----|------|
| Rated insulation voltage (Ui) | V | 1000 | | | |
| Rated Frequency | Hz | 50/60 | | | |
| Rated thermal current (Ith) | A | 2050 | | | |
| Utilization category | | AC-3 | | | AC-1 |
| Ambient temperature | °C | 55 | 55 | 55 | 40 |
| Rated operational voltage (Ue) | V | 1000 | 690 | 440 | 1000 |
| Rated operational current (Ie) | A | 425 | 350 | 800 | 2050 |

| Contactor type | | AF2650-30 | | | |
|--------------------------------|----|-----------|---|---|------|
| Rated insulation voltage (Ui) | V | 1000 | | | |
| Rated Frequency | Hz | 50/60 | | | |
| Rated thermal current (Ith) | A | 2650 | | | |
| Utilization category | | AC-3 | | | AC-1 |
| Ambient temperature | °C | - | - | - | 40 |
| Rated operational voltage (Ue) | V | - | - | - | 1000 |
| Rated operational current (Ie) | A | - | - | - | 2650 |

| Contactor type | | AF2850-30 | | | |
|--------------------------------|----|-----------|---|---|------|
| Rated insulation voltage (Ui) | V | 1000 | | | |
| Rated Frequency | Hz | 50/60 | | | |
| Rated thermal current (Ith) | A | 2850 | | | |
| Utilization category | | AC-3 | | | AC-1 |
| Ambient temperature | °C | - | - | - | 40 |
| Rated operational voltage (Ue) | V | - | - | - | 1000 |
| Rated operational current (Ie) | A | - | - | - | 2850 |

Technical data auxiliary contacts:

Auxiliary contacts CAL18-11

Rated control circuit voltage

Rated impulse withstand voltage Uimp

Conventional thermal current Ith

1 NO + 1 NC

24 – 690 V AC

6 kV

16 A

Application/Limitation

Environmental categories: Vibration A, Temperature D, Humidity B

Type Approval documentation

Technical info:

Catalogue 1SBC100214C0202 edition July 2020.

Test documentations:

| Document name | Type | Date |
|--------------------|---|------------|
| 1SBC100214C0202 | Extract of Main Product Catalog 2020, rev C | 2020-07 |
| 2CMT2021-006257 | Technical data - AF-contactor rev - | 2021-09-01 |
| 2CMT2020-006131 | Technical documentation AF400-AF2850 (IACS E10 rev7), rev - | 2020-10-14 |
| SE007580-1 | ISO9001-certificate ABB Sweden rev - | 2021-04-01 |
| 288199-2019-AQ-RGC | ISO9001-certificate ABB Xinhui, rev A | 2019-12-19 |
| 44100084221 | ISO9001-certificate ABB India rev - | 2020-11-25 |
| 1SFC380023-EN | Technical provision AF400-AF1250, rev Q | Apr 2021 |
| 1SFC101002M5501 | Technical provision AF1350-AF2050, rev V | Oct 2020 |
| 1SFC101050M0201 | Technical provision AF2650-AF2850, rev P | Feb 2020 |
| 1712331STO-001 | Environmental test, AF400-AF2850 | 2017-09-29 |
| 1714760STO-001 | CB test report for types AF400, AF460, rev - | 2017-12-20 |
| 1714763STO-001 | CB test report for types AF1350-AF2050 rev - | 2017-12-20 |
| 1714761STO-001 | CB test report for types AF580-AF1250, rev - | 2017-12-20 |
| 1810655VAS-001 | CB test report for types AF2650-AF2850 rev - | 2018-06-05 |
| SE-74013M2_CB | CB test certificate AF1350-AF2050 rev M2 | 2017-12-20 |
| SE-82863M1 | CB test certificate for types AF580-AF1250, rev M1 | 2017-12-20 |
| SE-82865M1 | CB test certificate AF1250 rev M1 | 2017-12-20 |
| SE-82316M2 | CB test certificate for types AF400, AF460, rev M2 | 2017-12-20 |
| SE-90984 | CB test certificate AF2650-AF2850 rev - | 2018-06-05 |
| REC-E702531_4 | EMC-test report AF460-AF1250 rev - | 2010-02-08 |
| REC-E702531_5 | EMC-test report AF460-AF1250 rev - | 2010-02-08 |
| REC-E704027 | EMC-test report AF460-AF1250 rev - | 2014-11-25 |
| 1013773 | EMC-test report AF460-AF1250 rev - | 2010-04-26 |
| 1120418-3 | EMC-test report AF1350-AF2850 rev - | 2011-10-31 |
| REC-E702531_6 | EMC-test report AF1350-AF2850 rev - | 2010-02-08 |
| 620-20237-13-R0 | EMC-test report AF1350-AF2850 rev - | 2020-10-20 |
| 620-20237-10-R0 | EMC-test report AF116-AF2850 (IACS E10 rev7) rev - | 2020-10-20 |
| 53540940-C | Assembly drawing, AF400-AF460, rev A | 2008-04-29 |
| 53540940_D | Assembly drawing, AF580-AF750, rev A | 2010-07-01 |
| 1SFB535001D1010 | Assembly drawing, AF1250, rev B | 2017-10-23 |
| 53540930-7 | Assembly drawing, AF1350-AF1650, rev C | 2014-05-09 |
| 1SFB535001G1035 | Assembly drawing, AF2050, rev B | 2014-01-03 |
| 1SFB535001G1045 | Assembly drawing, AF2650-AF2850, rev B | 2014-06-18 |

Tests carried out

Type tests according to IEC 60947-4-1(2009 +A1 2012) Sequence I and II,

Environmental tests in accordance with "Regulation for the Performance of Type Test Edition 2012" / IEC 60947-4-1

Annex Q: Power supply variations, Inclination test, Vibration test, Shock test, Insulation resistance test, Damp heat test, Dry heat test, Low temperature test and high voltage test. EMC in accordance with IACS E10 rev. 7.

Marking of product

ABB – Type designation – Rated voltage – Breaking capacity.

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine tests (RT) checked (if not available tests according to RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Assessment to be performed at 2 and 3,5 year and at renewal.

END OF CERTIFICATE